




NEW HORIZON
COLLEGE OF ENGINEERING

Autonomous College Permanently Affiliated to VTU, Approved by AICTE & UGC
Accredited by NBA and NAAC with Grade "A"



ENVIRONMENT AND ENERGY USAGE



This Environmental and Energy Policy is binding for all associated with the institution and obligatory for all stake holders and the operations -, academic, curricular, co-curricular and procurement activities undertaken by the institution. It will help us to invigorate the need to mitigate climate change and ingrain the environmental awareness into our thought process , routine activities and in particular sensitizing our students in their social responsibility towards the society and predominantly towards nature.

Worldwide, buildings are responsible for approximately 40% of the total world annual energy consumption. Most of this energy is for the provision of lighting, heating, cooling, and air conditioning. Therefore there is an exigent need to mitigate the carbon emissions .

Our primary environmental and energy objectives are to

- ❖ To assess our energy usage and measure its impact on the environment.
- ❖ To purpose design landscape and trees straddle for Green Campus
- ❖ To reduce air pollution emissions using eco-friendly vehicles, including bicycles, promoting public transportation and institutional transport services
- ❖ To explore all possible alternate energy sources to reduce carbon footprint
- ❖ To develop systematic waste management mechanism.
- ❖ Commitment to water sustainability and dedicated water management system, along with explicit rain water harvesting unit.
- ❖ To take additional measures to continuously improve our energy consumption
- ❖ To encourage use of advanced technology to minimize energy consumption, atmospheric emissions and noise, particularly from our vehicle fleets

- ❖ To offer carbon -neutral and eco-friendly power generation harnessing solar and wind energy
- ❖ To engage with KSPCB and create awareness about sustainable development.
- ❖ To provide information and training opportunities on energy saving measures.
- ❖ To enlighten our students and faculty through Green Energy Club which mainly concentrates in Creating awareness regarding the importance and methods of Energy Conservation along with its effective utilization
- ❖ To create an awareness on the need for and methodologies of environment preservation for a better tomorrow through club “Prakruthi”
- ❖ To build eco-friendly attitude amongst stake holders in campus and beyond through “Green club”

This policy will be communicated to the employees via internal communication channels, and will be made available to all the stakeholders on the institutional website. The Environment and Energy Policy, objectives and targets will be reviewed on a regular basis by the Committee Convener and its members under the guidance of the Principal/Registrar of the institution.

The Institution has formed a Energy Conversion Audit Committee which monitors the objectives of the environment and energy usage.

<https://newhorizonindia.edu/nhengineering/statutory-committee/#energy-conversion-audit-committee>

And, we also have student clubs

1.Prakruthi Club - <https://newhorizonindia.edu/co-curricular/prakruthi/>

2.Green Energy Club - <https://newhorizonindia.edu/cocurricular/greenenergy/>

These student clubs are regularly conduct activities with regard to Environment and Energy usage.

Apart from this we have NSS students club which are taking care of Clean and Green campus. <https://newhorizonindia.edu/extra-curricular/nss/>



**NEW HORIZON
COLLEGE OF ENGINEERING**
New Horizon Knowledge Park, Ring Road, Marathalli
Autonomous College Permanently Affiliated to VTU, Approved by AICTE & UGC
Accredited by NAAC with 'A' Grade, Accredited by NBA



Beyond the campus environmental promotion activities



Through
GREEN ENERGY CLUB (GEC)



Date:04.03.2021
Venue: Jakkur Lake


CLEANLINESS DRIVE

Green energy took responsibility of volunteering and helping an NGO, "Jala Poshan" along with the Green Warriors Club, NHCE.

The main objective was to keep the **Jakkur Lake** surroundings clean and sustaining the plants and trees by mulching and watering them. Around 40 club members volunteered the event



CLEANLINESS DRIVE



Date: 14.12.2020
Venue: ONLINE

GREEN FEST

“GREEN FEST” to bring out the best of the participants, to acquire knowledge on various topics and enhance the participants’ communication skills, creative skills and their knowledge about various locations.

We had conducted 4 events in the fest
Poster making
Where I am??
Thought bulb
Decipher.
Around 50 Participants participated in the fest



GREEN FEST



NEW HORIZON
COLLEGE OF ENGINEERING
Department of Electrical and Electronics Engineering

War of words

Debate Competition

Date : 11th Nov
Time : 2pm

Faculty coordinator
Mr. Vinod Kumar S
For more details
CONTACT
Student coordinators
Bindhu V
9620362611
Bhavana Singh
9846189086

Free registration

Register using
<https://forms.gle/GpaikctCLRvuv5B9>

An opportunity to showcase
your debating skills!!

E-Certificates will be provided to all participants
Conducted by
Green Energy Club,
Department of Electrical and
Electronics Engineering



Date:11.11.2021
Venue: ONLINE

WAR OF WORDS

“War of Words’ is organised to bring out the enthusiasm and ability of the students towards communication and create awareness, also to acquire knowledge on various topics Around 50 Participants participated in the Debate Competition

WAR OF WORDS



Date:06.11.2019
Venue:CTPS lab

NEW HORIZON
COLLEGE OF ENGINEERING
New Horizon Knowledge Park, Ring Road, Marathalli
Autonomous College Permanently Affiliated to VTU, Approved by AICTE & UGC
Accredited by NAAC with 'A' Grade, Accredited by NBA
DEPARTMENT OF ELECTRICAL AND ELECTRONICS ENGINEERING

GREEN ENERGY CLUB

GUEST LECTURE ON
ECO-BUILDING

BY : **P TARUN KUMAR S**
(CHUBB ALBA UTC ECO ENERGY)

Venue : CTPS LAB
Time: 10am-12pm
Date :6-11-2019

Faculty Coordinator
S Vinod Kumar

Student Coordinator
Hitish G (President)
Hemanth I (Secretary)



GUEST LECTURE ON “ECO BUILDING”

GUEST LECTURE ON “ECO BUILDING”

The Guest talk on Eco Building was organized by Green Energy Club to create awareness on Eco-Building System and to cater knowledge on Green buildings by Mr. P. Tarun Kumar S, Associate Engineer, CHUBB ALBA UTC ECO ENERGY. Around 35 students participated and benefited from the event.



**DO THE EARTH A
FAVOUR AND BE
A POWER SAVER**

*Reduce, Reuse,
and Recycle*



ಮನೆಗೊಂದು ಗಿಡ ಉರಿಗೊಂದು ವನ

Venue: Government Primary school
Doddanekundi
Date: 9/9/2019

**A STEP TOWARDS BRINGING A
CHANGE IN THE YOUNG MINDS**

ಹೌದು... ನಿಜಕ್ಕೂ ಈ ಪ್ರಕೃತಿ ಎಷ್ಟು ಸುಂದರವಾಗಿರುವುದು?
ನಮ್ಮ ಪ್ರಕೃತಿಯನ್ನೇ ಅಥವಾ ಹಸಿರು ಮರಗಳ ನಮ್ಮ
ಕುಳಿಬಿಡುವುದು ನಮ್ಮ ಮನಸ್ಸಿನಲ್ಲಿ ಶಾಂತಿ, ಪ್ರೀತಿಯ ಭಾವನೆಗಳು
ಅವರಿಸಿಕೊಂಡಿರುತ್ತವೆ. ಆದರೆ ನಾವು ಅಂತಹ ಪ್ರಕೃತಿಯನ್ನು ಗಾಂಧಿ ನೆತ್ತಿ
ಮುಂದೆ ಉಳಿದಂತೆ ವ್ಯಕ್ತಿಯೊಬ್ಬನ ಬಾಂಧವ್ಯ ಪಡೆದು




SCHOOL CAMPAIGN ON ENERGY CONSERVATION

Date:09.09.2019
Venue: Government
Primary School,
Doddanekudi

SCHOOL CAMPAIGN ON ENERGY CONSERVATION

The Green energy was organized SCHOOL CAMPAIGN ON ENERGY CONSERVATION To create awareness on energy conservation among school students. Explain the importance of electrical energy. To improve school student's knowledge about renewable energy Around 35 club members educated around 300 school students



GUEST TALK ON “Energy Auditing Made Easy”

Date:23.03.2019
Venue:CTPS lab

GUEST TALK ON “Energy Auditing Made Easy”

The Guest talk on Eco Building was organized by Green Energy Club to cater the basic knowledge on Energy Audit & Energy Conservation and To acquire knowledge on Power Distribution & Transmission. Er.A. Ramesh Executive Engineer (Ele), BESCOM, Around 35 students participated and benefited from the event.



GREEN WEEK

Date: 29.10.2018
Venue: NHCE campus

GREEN WEEK

The Green energy was organized GREEN WEEK in college campus To create awareness about energy conservation in modern day lifestyle To educate the importance about energy resources To know necessity of energy conservation. Around 35 club members educated around 600 college students of various departments.



SCHOOL CAMPAIGN ON ENERGY CONSERVATION

Date:02.10.2018
Venue: Government school, Marathahalli, Bangalore

SCHOOL CAMPAIGN ON ENERGY CONSERVATION

The Green energy was organized SCHOOL CAMPAIGN ON ENERGY CONSERVATION To create awareness on energy conservation among school students. Explain the importance of electrical energy. To improve school student's knowledge about renewable energy Around 35 club members educated around 200 school students





Date:02.11.2018
Venue: Government
Model Primary school
Kudlu, Bangalore

SOCIAL AND GREEN OUTREACH PROGRAM

Social and green outreach program has been organized to government model primary school teachers by E-Soft club in association with green warrior club.

The program had three events Giving Training to school teachers on MS Excel. Giving awareness about the energy conservation to school students. Planting the green plants around the play ground



SOCIAL AND GREEN OUTREACH PROGRAM

Awareness in campus –corridors, rooms





AICTE National level

CLEAN & SMART CAMPUS AWARDS-2019

A CAMPUS FIRST STEP TOWARDS SUSTAINABILITY

CERTIFICATE *of Appreciation*

Awarded to

NEW HORIZON COLLEGE OF
ENGINEERING (E&T)
Karnataka

FOR THEIR SELECTION & ACTIVE PARTICIPATION
FOR CAMPUS VISIT



DATE: 03.12.2019

Prof. Anil D. Sahasrabudhe
Chairman, AICTE



NEWS

[Home](#) » [Blog](#) » [News](#) »

NHCE organised Swachhta hi seva under SWACHHA BHARATH ABHIYAN to bring awareness about clean India on the occasion of Mahatma Gandhi Jayanthi on 2nd October at Bellandur

NHCE organised Swachhta hi seva under SWACHHA BHARATH ABHIYAN to bring awareness about clean India on the occasion of Mahatma Gandhi Jayanthi on 2nd October at Bellandur

Categories
NEWS

Date
OCTOBER 2, 2017



i) Hygiene and cleanliness maintenance at college campus: "SWACHH BHARAT ABHIYAN" taken up by Government of India is a wonderful initiative of keeping our surroundings clean. As sole responsible citizens, NHCE has taken up this initiative to keep the campus clean. The college campus is well maintained. The corridors, classes and toilets are cleaned every day with regular check procedures as a part of hygiene management. There is a proper waste management procedure employed at NHCE, where the waste is segregated into domestic hazardous waste, biodegradable waste and non-biodegradable waste.

Instead of dumping the collected waste elsewhere and pollute the surroundings, NHCE cares for a proper management of the waste collected in campus, by further processing (the Biodegradable waste) in the treatment plant – THE ORGANIC WASTE CONVERTER, installed well within the campus. The converter is used for converting the entire biodegradable waste collected not only from all the green bins but also from the food waste collected at Boys & Girls hostels. After a three –four day treatment process that happens in the converter, we get organic manure, which is again used for the plants grown within the campus. Contents collected in Red Bin (domestic hazard waste) and Blue Bin (non biodegradable waste) will be dumped into the collection rooms present within the campus (painted in red and blue respectively) which will be cleared periodically.



SEARCH



CATEGORIES

[ACCOLADES](#)
[ALUMNI MEET](#)
[ALUMNI SPORTS MEET](#)
[BLOG](#)
[CAREER](#)
[CLUB ACTIVITIES](#)
[COLLABORATIONS](#)
[COMPUTER SOCIETY OF INDIA](#)
[EDC NEWS](#)
[ELECTRONIC](#)
[FACILITIES](#)
[GALLERY](#)
[INDUCTION PROGRAM](#)
[INDUSTRY INSTITUTE INTERACTION](#)
[INDUSTRY SPONSORED LABS](#)
[MEDIA](#)
[NEWS](#)
[PRINT](#)
[PROFESSIONAL COUNSELLING](#)
[PROFESSIONAL COUNSELLING ARTICLES](#)
[SPORTS VIDEO](#)
[STUDENT CLUB](#)
[UNCATEGORIZED](#)
[UNNAT BHARAT ABHIYAN](#)



ii) Plantation of trees and eco-friendly campus: NHCE has a very healthy environment with lush green landscaping. Regular tree plantation and maintenance activities are conducted in the campus and on 27th September 2017 Swachhta Hi Seva campaign was conducted where plantation activities were included.



iii) Rain water harvesting and Sewage treatment Plant: NHCE has a very efficient rain water harvesting setup installed from all the building and a common drain and collection point for the water to go for further filtration setup. The recycled water is used for flushing purposes in toilets and also for watering the trees within the campus.



iv) Swachhta Pledge: Swachhta Pledge was taken by all the students & staff of NHCE at the Swachhta

Hi Seva campaign conducted on 27th September 2017. The campaign was also marked by poster display by students

with slogans of Swachhta and importance of Hygiene Management.



v) Hygiene sensitisation programme at Bellandur Village, Bangalore – New Horizon college of Engineering in collaboration with local youth and government officials of Bellandur Village took

initiative of cleaning the locality and further educated the people about the importance of cleanliness.



vi) Future plans & Initiatives taken up by New Horizon Educational Institutions (NHEI) for Swachh Bharath Abhiyan:





Dr. Mohan Manghnani, Chairman NHEI, handing over Rs.5 Crore cheque to the Honourable Prime Minister of India Shri. Narendra Modi as a contribution towards Swachh Bharat Abhiyan



Requisition sent from NHEI to the concerned authorities for allocating a village in rural area for adoption and carrying out developmental activities at the village, which is a Societal Outreach activity initiated by the Trust.

Share:

Previous post

5 signs it's time to find a new job
October 2, 2017

Next post

Expert talk on machine learning by Mr Ranjit Gupta from SAP in association with training and placement department for faculty members of ECE ISE and ME.
October 3, 2017

YOU MAY ALSO LIKE



Dr. Mohan Manghnani, Chairman of New Horizon Educational Institutions, presented a cheque of Rs.5 Crores towards the Ram Mandir Trust
5 March, 2021



Commencement of NCC- Chapter in NHCE
1 March, 2021

Our
sem
mai
'Tim
24 Fi



+91-80-6629 7777
+91-9880534935 / +91-9740076446



Bellandur Main Rd, Kaverappa Layout,



admissionsnhce@newhorizonindia.edu

Near Marathahalli, Bengaluru -
560103



New Horizon College of
Engineering is an
Autonomous college
affiliated to Visvesvaraya
Technological
University(VTU).



QUICK LINKS

[News](#)
[Research](#)
[Celebrity Diaries](#)
[Online Payment](#)

USEFUL LINKS

[Web Mail](#)
[Admissions](#)
[Programs](#)
[Industry Institute](#)
[Interaction Cell](#)
[IEEE NHCE Student Branch](#)
[CSI - NHCE Student
Branch](#)
[News Letters](#)

99936267-
Shivika - JEN/

Draft Report
Project code: 2016IB15

January 2017

Energy Audit Report of New Horizon College of Engineering



teri

The Energy and Resources Institute

...towards global
sustainable development

Executive Summary

- 1.0 This section presents a brief summary of the results of the comprehensive energy audit carried out at **New Horizon College of Engineering (NHCE)** in November 2016. The study covered with a focus on energy conservation measures including performance assessment of vital energy consuming equipment.
- 2.0 A team of three consultants were involved in the comprehensive energy audit study. The energy audit was mainly targeted at identifying practical, sustainable and economically viable energy saving opportunities in all sections of the facility, resulting from a detailed study and analyses of technical parameters. The energy audit involved using a wide range of sophisticated, portable, diagnostic and measuring instruments to generate refined data and facilitate in complex analyses to give a more reliable basis for evaluation of performance, energy saving measures and economic viability.
- 3.0 Electricity & Diesel are the major sources of energy to the facility. Diesel procurement and consumption details are not readily available to estimate the fuel share. The daily diesel consumption has to be monitored for the better accounting. The study has identified eight energy conservation proposals. The EC proposals were grouped with respect to the small, medium and large investment and their paybacks were calculated. The table below gives the total number of proposals, savings, and investment with payback period.

The savings that can be achieved with small and large investment are sizable.

Type of Recommendations	No. of recommendations	Annual Saving Potential	Cost of Implementation Rs. in lakh	Payback Period, Years
		In Rupees	In Rupees	
Short term investment, payback less than 1 year	4	435100	164200	0.4
Medium term investment, payback period between 1-3 year	1	11940	24000	2
Long term investment, payback above 3 years	3	946000	4257000	4.5
Total	8	1393040	4445200	3.2

The energy audit study has identified an annual electrical energy saving potential of **1.67 Lakh kWh + 329kVA per annum**. The annual electrical energy savings works out to be 13.3% of the annual electrical energy consumption (12.57 Lakh kWh*) for the year 2015-16. The total cost of implementation for the recommended proposals is estimated to be **Rs 44.45 Lakhs** with a simple payback period of **3.2 years**.

All energy conservation proposals fall in short and medium term investment oriented proposals and with simple payback period of varying from 1 to 3 years.

4.0 During the study, there was continuous interaction with the facility personnel, all the recommendations have been thoroughly discussed with concerned facility officials and also at group meetings. There has been close involvement of senior officials, which ensured the necessary co-ordination required for the study.

5.0 A summary list of recommendations, the saving potential and implementation costs is given below:

S.No	Energy Conservation Measures	Annual Savings Potential		Investment	Simple payback period
		Electricity,	Value, Rs	Rs Lakhs	Years
		kWh / kVA		₹	
SHORT TERM MEASURES					
Electrical Systems					
1	Rectify the faulty capacitors in the APFC and improve the system power factor to unity.	49kVA	8820	9200	1.0
2	Minimising the Maximum demand by installing the Maximum Demand Controller	280 kVA	50400	30000	0.6
Electrical Drives					
3	Overhaul the aeration blowers for improved performance in STP	3000	23880	25000	1
Solar Water Heater System					
4	Proper utilisation of Solar water heater and avoid Geyser operation in the morning	44,160	352000	100000	0.3
	Sub-Total	47160kWh + 329 kVA	435100	164200	0.4
MEDIUM TERM MEASURES					
5	Replace the existing old transfer pumps with new energy efficient pumps in STP	1500	11940	24000	2
	Sub-Total	1500	11940	24000	2
LONG TERM MEASURES					
Lighting Systems					
6	Replace the existing T12/ T8 Fluorescent Tube Lights with 19W LED Tube Lights	76520	609000	1966000	3.2
7	Replacement of 400W Metal Halide with 200W Induction lamps	10,746	86000	320000	3.7
8	Replace the existing 65W conventional ceiling fans with BLDC Fan of 28W	31528	251000	1971000	7.9
	Sub-Total	118,794	946000	4257000	4.5
	Grand Total	167454+ 329 kVA	1393040	4445200	3.2

Appendix List

Appendix No.	Description
3.	Facility Overview
3/1-3/3	Present Power Cost at New Horizon College of Engineering
4.	Electrical systems
4/1	Measured Power Parameters of EB Incoming (24-11-2016 to 25-11-2016)
4/2	Measured Power Parameters of EB Incoming (26-11-2016 to 27-11-2016)
4/3	Main DB Power distribution
4/4	Blockwise Power distribution
6.	Electrical Drives
6/1	Measured power parameters of Electrical Drives
6/2	Measured Load Parameters of STP
6/3	Performance analysis of AC Units
7.	Lighting Systems
7/1	Connected Light Load Details
7/2	Lux Details
7/3	Savings By Replacing T12/T8 Fluorescent Tube Lights by 19W LED Tube Light
8.	Diesel Generator
8/1	Measured power parameters of DG set
8/2	Performance test of the 500KVA dg set
8/3	DG LOG SHEET

Present Power Cost at New Horizon College of Engineering, Bangalore

Present Power Cost at New Horizon College of Engineering, Bangalore					
Bill for the month of September 2016			Type	HT2C	Tariff 1HT2C2
Contract Demand				400	KVA
75% CD				300	KVA
Recorded Demand				316	KVA
Consumption details			Consumption (KVAh)		Consumption (KWh)
			113420 KVAh		111460 KWh
Less/ Add Consumption			0	KVAh	0 kWh
Total purchased power					111460 KWH
Average PF				0.98	
Sl. No.	Particulars	Qty.	Unit	Rate/unit (Rs.)	Amount (Rs.)
Demand Charges					
a)	Billing Demand Charge	316	KVA	180.00	56880.00
b)	Excess Demand Charge	0	KVA	360.00	0.00
c)	Total Demand Charges (a+b)				56880.00
Energy Charge					
d)	Energy Charge: First 100000kWh	100000	KWH	7.00	700000.00
e)	Energy Charge: More than 100000kWh	11460	KWH	7.50	85950.00
f)	Total Energy Charge (d+e)				785950.00
g)	Interest on revenue				100.00
h)	Tax				47157.00
i)	Current Bill Amount (c+f+g+h)				890087.00
j)	Prompt Payment Incentive				2206.89
Net Payable Amount (i-j)					Rs.887,880
Overall energy cost per unit					Rs.7.97

Present Power Cost at New Horizon College of Engineering, Bangalore

Bill for the month of October 2016		Type	HT2C	Tariff 1HT2C2	
Contract Demand			400	KVA	
75% CD			300	KVA	
Recorded Demand			311	KVA	
Consumption details		Consumption (KVAh)		Consumption (KWh)	
		117580	KVAh	116000	KWh
Less/ Add Consumption		0	kVAh	0	kWh
Total purchased power				116000	KWH
Average PF				0.98	
Sl. No.	Particulars	Qty.	Unit	Rate/unit (Rs.)	Amount (Rs.)
Demand Charges					
a)	Billing Demand Charge	311	KVA	180.00	55980.00
b)	Excess Demand Charge	0	KVA	360.00	0.00
c)	Total Demand Charges (a+b)				55980.00
Energy Charge					
d)	Energy Charge: First 100000kWh	100000	KWH	7.00	700000.00
e)	Energy Charge: More than 100000kWh	16000	KWH	7.50	120000.00
f)	Total Energy Charge (d+e)				820000.00
g)	Interest on revenue				100.00
h)	Tax				49200.00
i)	Current Bill Amount (c+f+g+h)				925280.00
j)	Prompt Payment Incentive				2219.70
Net Payable Amount (i-j)					Rs.923,060
Overall energy cost per unit					Rs.7.96

Present Power Cost at New Horizon College of Engineering, Bangalore

Present Power Cost at New Horizon College of Engineering, Bangalore						
Bill for the month of November 2016			Type	HT2C	Tariff 1HT2C2	
Contract Demand				400	KVA	
75% CD				300	KVA	
Recorded Demand				295	KVA	
Consumption details			Consumption (KVAh)		Consumption (KWh)	
			117460	KVAh	115520	KWh
Less/ Add Consumption			0	kVAh	0	kWh
Total purchased power				115520	KWH	
Average PF				0.98		
Sl. No.	Particulars	Qty.	Unit	Rate/unit (Rs.)	Amount (Rs.)	
Demand Charges						
a)	Billing Demand Charge	300	KVA	180.00	54000.00	
b)	Excess Demand Charge	0	KVA	360.00	0.00	
c)	Total Demand Charges (a+b)				54000.00	
Energy Charge						
d)	Energy Charge: First 100000kWh	100000	KWH	7.00	700000.00	
e)	Energy Charge: More than 100000kWh	15520	KWH	7.50	115400.00	
f)	Total Energy Charge (d+e)				815400.00	
g)	Interest on revenue				100.00	
h)	Tax				48984.00	
i)	Current Bill Amount (c+f+g+h)				919484.00	
j)	Prompt Payment Incentive				2307.65	
Net Payable Amount (i-j)					Rs.917,176	
Overall energy cost per unit					Rs.7.94	

Measured Power Parameters of EB Incomer (24-11-2016 to 25-11-2016) During Working day

Date	Time	Hz	Voltage (V)			Vunb	%Vthd			Current (A)			Aunb	%Athrd			kW			kVAR			kVA	PF			MWh
			L1	L2	L3		%	L1	L2	L3	L1	L2		L3	%	L1	L2	L3	Sum	Sum	Sum	Sum		Sum	L1	L2	
24-11-2016	6:00	50.04	415	418	418	0.40	1.95	1.95	1.95	191	183	269	28.85	12.25	12.10	12.05	123	50	150	0.98	0.99	0.98	0.98	0.99	0.98	61	
24-11-2016	6:30	50.02	414	417	417	0.40	2.00	2.00	2.00	182	152	326	43.00	12.90	13.50	13.80	110	37	161	0.96	0.99	0.99	0.96	0.99	0.99	120	
24-11-2016	1:00	50.02	417	419	419	0.40	1.90	1.90	1.90	172	148	273	36.75	13.00	13.75	13.90	112	29	147	0.99	0.99	0.99	0.99	0.99	0.99	176	
24-11-2016	1:30	50.02	419	421	421	0.40	1.96	1.96	1.96	165	147	193	15.15	13.20	14.00	14.30	108	41	122	0.98	0.98	0.98	0.98	0.98	0.98	230	
24-11-2016	2:00	50.05	422	424	424	0.40	1.96	1.96	1.96	157	143	209	23.05	13.00	13.85	14.45	104	40	124	0.99	0.99	0.99	0.99	0.99	0.99	282	
24-11-2016	2:30	50.06	421	423	423	0.35	1.90	1.95	1.90	146	132	188	24.00	14.10	15.00	15.80	95	43	116	0.99	0.99	0.99	0.99	0.99	0.99	329	
24-11-2016	3:00	50.03	421	424	424	0.40	1.80	1.90	1.90	150	123	233	37.45	13.30	14.45	16.90	94	49	124	0.99	0.98	0.98	0.99	0.98	0.98	376	
24-11-2016	3:30	50.01	420	423	423	0.40	1.80	1.85	1.85	147	117	270	47.90	13.40	14.80	17.20	91	27	102	0.99	0.99	0.99	0.99	0.99	0.99	421	
24-11-2016	4:00	50.00	421	423	424	0.40	1.80	1.90	1.85	147	119	152	14.90	13.55	15.15	17.50	91	27	102	0.99	0.99	0.99	0.99	0.99	0.99	510	
24-11-2016	4:30	50.00	420	423	423	0.45	1.70	1.80	1.80	142	113	140	14.25	13.55	14.35	17.70	87	21	96	0.99	0.99	0.99	0.99	0.99	0.99	550	
24-11-2016	5:00	50.01	417	420	420	0.50	1.60	1.85	1.80	160	160	116	13.55	13.15	14.85	16.95	91	15	98	0.99	0.99	0.99	0.99	0.99	0.99	605	
24-11-2016	5:30	49.97	409	412	412	0.45	1.85	1.85	1.85	160	160	116	13.55	13.15	14.85	16.95	98	18	103	0.99	0.99	0.99	0.99	0.99	0.99	662	
24-11-2016	6:00	49.98	408	412	412	0.55	1.85	1.85	1.85	160	160	116	13.55	13.15	14.85	16.95	115	41	131	0.99	0.99	0.99	0.99	0.99	0.99	738	
24-11-2016	6:30	50.00	411	414	414	0.35	1.80	1.75	1.80	160	130	143	227	35.40	10.25	11.40	11.85	115	41	168	0.99	1.00	0.99	1.00	0.99	1.00	805
24-11-2016	7:00	50.01	400	402	403	0.45	1.35	1.25	1.25	180	195	196	407	52.25	8.60	7.55	7.05	151	41	405	0.99	1.00	1.00	1.00	0.99	1.00	876
24-11-2016	7:30	49.88	401	403	405	0.50	1.10	1.05	1.10	214	186	1339	125.40	7.40	7.20	7.40	9.85	134	108	405	0.99	1.00	1.00	1.00	0.99	1.00	945
24-11-2016	8:00	49.97	404	406	407	0.45	1.10	1.00	1.00	198	197	343	37.10	0.40	8.05	8.36	140	50	173	1.00	1.00	1.00	1.00	0.99	0.99	1030	
24-11-2016	8:30	50.00	402	404	405	0.45	1.05	1.05	1.05	240	250	257	4.85	7.50	7.00	7.15	172	24	174	1.00	0.99	0.99	1.00	0.99	0.99	1129	
24-11-2016	9:00	49.98	398	400	401	0.45	1.00	0.95	1.00	267	281	350	14.20	6.25	6.35	6.45	107	38	215	1.00	0.99	0.99	1.00	0.99	0.99	1237	
24-11-2016	9:30	50.00	392	393	395	0.40	0.95	0.95	0.95	305	331	1087	89.75	6.10	5.95	7.80	215	153	434	1.00	0.99	0.99	1.00	0.99	0.99	1342	
24-11-2016	10:00	50.01	390	391	392	0.30	1.10	1.10	1.10	295	316	700	80.30	7.10	6.50	6.90	211	155	296	1.00	0.99	0.99	1.00	0.99	0.99	1451	
24-11-2016	10:30	49.98	393	394	395	0.30	1.20	1.20	1.20	307	324	1637	110.30	7.20	7.05	9.85	211	185	534	1.00	0.99	0.99	1.00	0.99	0.99	1570	
24-11-2016	11:00	49.98	394	395	397	0.30	1.15	1.10	1.10	338	353	520	28.90	5.90	5.90	6.20	239	106	277	1.00	0.99	0.99	1.00	0.99	0.99	1686	
24-11-2016	11:30	50.02	393	394	395	0.30	1.20	1.15	1.15	328	344	503	28.35	6.10	6.00	6.40	231	98	287	1.00	0.99	0.99	1.00	0.99	0.99	1801	
24-11-2016	12:00	50.00	392	394	394	0.30	1.25	1.25	1.25	331	338	433	17.85	6.20	6.30	6.90	230	72	250	1.00	0.99	0.99	1.00	0.99	0.99	1906	
24-11-2016	12:30	49.85	394	395	397	0.35	1.20	1.20	1.20	315	268	417	22.85	6.20	7.30	7.15	211	68	233	1.00	0.99	0.99	1.00	0.99	0.99	2005	
24-11-2016	13:00	50.03	401	403	404	0.40	1.35	1.30	1.30	295	295	280	469	36.45	7.25	8.40	8.50	197	83	239	1.00	0.99	0.99	1.00	0.99	0.99	2103
24-11-2016	13:30	50.02	409	412	412	0.40	1.50	1.45	1.50	283	281	1014	94.50	8.05	8.55	9.55	197	58	375	1.00	0.99	0.99	1.00	0.99	0.99	2202	
24-11-2016	14:00	49.96	407	409	409	0.35	1.60	1.55	1.60	283	285	1183	104.75	8.30	9.15	10.00	197	227	410	1.00	0.99	0.99	1.00	0.99	0.99	2297	
24-11-2016	14:30	49.95	401	404	404	0.40	1.60	1.60	1.60	277	250	525	49.70	8.30	8.25	10.05	190	81	245	1.00	0.99	0.99	1.00	0.99	0.99	2383	
24-11-2016	15:00	49.98	399	401	402	0.40	1.40	1.45	1.45	287	271	554	46.45	7.35	8.35	10.40	192	53	257	1.00	0.99	0.99	1.00	0.99	0.99	2488	
24-11-2016	15:30	49.88	395	398	398	0.40	1.40	1.45	1.45	281	270	380	22.45	7.45	8.50	9.90	191	60	214	1.00	0.99	0.99	1.00	0.99	0.99	2567	
24-11-2016	16:00	49.92	393	395	395	0.40	1.45	1.45	1.45	229	218	364	33.00	8.20	9.45	11.35	158	32	187	0.92	0.92	0.92	0.92	0.92	0.92	2567	
24-11-2016	16:30	49.93	397	399	399	0.40	0.70	0.65	0.70	0	0	230	200.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2567	
24-11-2016	17:00	49.96	397	399	400	0.35	0.85	0.85	0.85	57	53	123	112.90	2.40	2.90	10.90	38	-12	53	0.27	0.27	0.27	0.27	0.27	0.27	2566	

Electrical system

Date	Time	Hz	Voltage (V)			Vumb			%Vlhd			Current (A)			Aumb			%Aumb			KW			KVA			PF			kWh
			L1	L2	L3	%	L1	L2	L3	L1	L2	L3	%	L1	L2	L3	%	L1	L2	L3	Sum	Sum	Sum	Sum	Sum	L1	L2	L3		
24-11-2016	17:30	50.00	396	398	399	0.60	1.15	1.15	1.15	241	214	259	10.55	6.75	8.80	8.30	155	16	164	1.00	0.99	0.87	2604	0.87	0.99	0.90	0.90	2747		
24-11-2016	18:00	49.99	396	401	402	0.50	1.15	1.15	1.20	245	231	271	8.75	7.45	8.05	7.50	166	22	173	0.99	0.99	0.90	2747	0.90	0.99	0.90	0.90	2846		
24-11-2016	18:30	50.05	403	406	407	0.50	1.15	1.20	1.25	307	273	299	6.73	6.50	7.15	7.25	199	49	206	0.99	0.99	0.92	2846	0.92	0.99	0.90	0.90	2951		
24-11-2016	19:00	50.03	407	411	419	0.55	1.25	1.35	1.40	331	268	312	11.70	6.95	7.45	7.35	209	46	215	0.99	0.99	0.84	2951	0.84	0.99	0.90	0.90	3052		
24-11-2016	19:30	50.02	412	416	418	0.65	1.40	1.45	1.50	326	251	296	14.05	7.00	7.90	7.95	203	47	210	0.99	0.99	0.83	3052	0.83	0.99	0.90	0.90	3148		
24-11-2016	20:00	50.02	413	418	418	0.70	1.40	1.55	1.60	322	243	280	17.26	7.15	8.05	8.75	191	49	198	0.99	0.99	0.91	3148	0.91	0.99	0.90	0.90	3236		
24-11-2016	20:30	50.01	417	421	422	0.65	1.55	1.75	1.75	255	220	241	19.05	7.75	8.90	10.95	177	47	184	0.98	0.98	0.89	3236	0.89	0.98	0.90	0.90	3317		
24-11-2016	21:00	50.03	419	423	422	0.60	1.65	1.85	1.90	264	199	236	14.76	8.45	10.70	11.50	162	48	170	0.98	0.98	0.87	3317	0.87	0.98	0.90	0.90	3465		
24-11-2016	21:30	50.09	417	421	421	0.60	1.70	1.90	1.90	256	187	231	16.86	10.10	11.60	12.45	154	48	163	0.98	0.98	0.84	3465	0.84	0.98	0.90	0.90	3534		
24-11-2016	22:00	50.05	416	420	421	0.60	1.80	1.95	2.00	241	178	207	13.76	11.20	12.55	14.85	142	-8	151	0.99	0.99	0.93	3534	0.93	0.99	0.90	0.90	3603		
24-11-2016	22:30	50.02	414	417	417	0.55	1.90	2.00	2.15	226	172	202	13.90	12.25	12.00	14.20	138	-9	144	0.95	0.95	0.90	3603	0.90	0.95	0.90	0.90	3666		
24-11-2016	23:00	50.03	420	423	423	0.50	1.95	2.00	2.10	218	176	194	11.20	12.35	10.90	14.10	138	-4	143	0.99	0.99	0.91	3666	0.91	0.99	0.90	0.90	3768		
24-11-2016	23:30	50.04	422	425	426	0.50	2.00	2.10	2.15	203	173	180	9.60	13.25	11.35	15.60	131	-20	136	0.99	0.99	0.89	3768	0.89	0.99	0.90	0.90	3868		
Average Total		50.00	407	410	416	0.44	1.48	1.51	1.53	231	208	414	40.08	9.10	9.55	11.42	153	36	204	0.95	0.95	0.88		0.88	0.95	0.95	0.95	3868		
Maximum		49.98	394	396	397	0.30	1.15	1.15	1.10	338	353	520	28.90	5.9	6.2	6.2	239	106	277	1.00	0.99	0.89		0.89	0.99	0.99	0.99	3868		
Minimum		49.93	397	399	395	0.40	0.70	0.65	0.70	0	0	230	220.00	0.0	0.0	24.7	0	-12	53	0.00	0.00	0.03		0.03	0.00	0.00	0.03			

TERI Report No. 2016/1815

Measured Power Parameters of EB Incomer (26-11-2016 to 27-11-2016) During Holiday

Date	Time	Hz	Voltage (V)			Vunb	%Vunb			Aunb	%Aunb			kW	kVAR		Sum	kVA	PF			MWh	
			L1	L2	L3		L1	L2	L3		L1	L2	L3		L1	L2			L3				
26-11-2016	0:00	49.99	421	424	424	0.50	2.25	2.30	2.30	148.90	143.63	14.90	14.75	14.35	17.40	114.73	-11.79	115.67	0.92	0.99	0.97	57	
26-11-2016	0:30	49.99	422	425	425	0.50	2.25	2.30	2.30	148.80	146.80	14.85	14.50	14.80	17.30	114.46	-19.30	115.67	0.99	0.98	0.97	115	
26-11-2016	1:00	49.99	422	425	425	0.45	2.25	2.30	2.30	178.45	141.95	16.30	14.55	15.60	17.60	110.60	-15.46	112.75	0.99	0.98	0.97	170	
26-11-2016	1:30	49.98	413	415	415	0.50	2.25	2.30	2.30	175.30	138.45	14.15	14.95	16.55	17.30	107.22	-9.53	108.97	0.99	0.98	0.98	224	
26-11-2016	2:00	50.00	414	417	417	0.45	2.20	2.30	2.25	167.45	132.35	14.70	14.90	15.85	18.25	103.46	-13.11	105.17	0.99	0.99	0.98	275	
26-11-2016	2:30	50.01	411	413	414	0.45	2.15	2.20	2.15	165.50	138.15	13.15	14.15	13.95	15.60	102.33	-0.44	103.60	0.99	0.99	0.98	325	
26-11-2016	3:00	50.00	412	415	415	0.45	2.10	2.20	2.20	158.75	133.00	13.35	12.05	13.75	14.15	100.50	-4.53	101.71	0.99	0.99	0.98	377	
26-11-2016	3:30	49.97	411	414	414	0.40	2.20	2.20	2.20	157.70	133.90	13.20	11.65	14.15	14.50	101.75	-11.35	101.11	0.99	0.99	0.98	427	
26-11-2016	4:00	49.98	412	415	415	0.40	2.15	2.20	2.20	160.40	137.20	13.35	11.65	13.75	14.10	101.75	-5.28	103.01	0.99	0.99	0.98	477	
26-11-2016	4:30	50.02	410	413	413	0.40	2.15	2.20	2.20	170.65	148.80	14.40	10.40	13.00	14.95	109.29	0.52	113.49	0.99	0.99	0.99	532	
26-11-2016	5:00	50.02	407	410	410	0.40	2.10	2.10	2.20	170.75	148.05	14.40	10.60	12.70	12.95	108.23	3.92	108.32	0.99	0.99	0.99	586	
26-11-2016	5:30	49.95	400	403	403	0.40	2.10	2.10	2.15	187.75	148.75	14.00	10.25	12.30	12.05	104.94	-1.02	105.05	0.99	0.99	0.98	639	
26-11-2016	6:00	50.02	406	408	408	0.45	1.90	1.95	2.05	164.40	152.15	14.85	8.85	10.55	10.00	107.97	-5.06	108.88	0.99	0.99	0.99	693	
26-11-2016	6:30	50.04	405	409	408	0.50	1.90	1.90	1.90	178.95	154.05	12.30	9.30	9.35	9.10	123.45	-8.59	124.22	0.99	0.99	0.99	754	
26-11-2016	7:00	50.02	399	403	402	0.50	1.90	1.85	1.90	200.90	172.95	10.85	8.45	8.50	8.55	134.25	-2.20	134.89	1.00	0.99	0.99	822	
26-11-2016	7:30	49.99	404	408	408	0.60	1.80	1.85	1.90	188.80	157.80	11.45	8.95	9.00	9.55	124.71	-8.05	125.48	1.00	0.99	0.99	864	
26-11-2016	8:00	50.00	406	409	409	0.55	1.90	1.90	2.00	180.40	160.25	17.40	6.40	10.20	9.85	11.35	120.02	-11.24	120.93	0.99	0.99	944	
26-11-2016	8:30	50.02	405	408	408	0.50	1.90	1.90	1.90	220.95	197.50	8.40	8.75	8.20	8.80	151.47	-8.25	152.28	1.00	0.99	0.99	1020	
26-11-2016	9:00	50.02	403	407	407	0.60	1.80	1.80	1.90	234.80	240.35	8.95	8.90	6.70	8.30	183.12	0.04	183.80	1.00	1.00	0.99	1111	
26-11-2016	9:30	50.00	400	404	406	0.70	1.85	1.90	1.95	340.70	273.30	14.65	6.05	6.45	8.60	206.59	5.04	207.37	1.00	0.99	1.00	1214	
26-11-2016	10:00	15.24	125	126	126	0.50	0.65	0.65	0.65	56.95	50.70	10.85	1.65	1.55	2.00	36.91	2.40	37.59				1233	
26-11-2016	10:30																					1233	
26-11-2016	11:00																					1233	
26-11-2016	11:30																					1233	
26-11-2016	12:00																					1233	
26-11-2016	12:30																					1233	
26-11-2016	13:00																					1233	
26-11-2016	13:30																					1233	
26-11-2016	14:00																					1233	
26-11-2016	14:30																					1233	
26-11-2016	15:00																					1233	
26-11-2016	15:30																					1233	
26-11-2016	16:00	25.41	207	209	209	0.70	1.35	1.35	1.35	109.40	90.85	116.55	106.40	5.90	6.00	72.79	4.36	73.63				1259	
26-11-2016	16:30																					1259	
26-11-2016	17:00	49.92	404	408	408	0.60	2.10	2.20	2.20	279.75	233.50	267.85	10.35	7.35	8.30	9.05	162.61	10.19	183.34	1.00	1.00	0.99	1361

Supply Failure

Supply Failure

Electrical Systems

Date	Time	Hz	Voltage (V)			Vamb	%Vbhd			Current (A)			Aamb	%Aabhd			KW	KVA			PF	KWH	
			L1	L2	L3		L1	L2	L3	L1	L2	L3		L1	L2	L3		Sum	Sum	Sum			
26-11-2016	17:30	40.88	404	407	408	0.52	1.90	2.05	2.05	209.20	223.90	231.15	3.45	8.40	8.30	10.20	162.12	162.95	162.95	1.00	1.00	0.99	1442
26-11-2016	18:00	49.97	404	407	408	0.60	1.85	2.05	2.10	215.80	211.95	187.15	10.90	9.80	9.50	12.95	145.57	146.65	146.65	0.99	0.99	0.99	1514
26-11-2016	18:30	49.96	400	402	403	0.50	2.10	2.25	2.40	264.55	251.45	232.80	6.75	11.30	9.45	12.45	172.47	173.69	173.69	0.99	1.00	0.99	1601
26-11-2016	19:00	50.03	402	405	406	0.55	2.00	2.10	2.30	266.95	260.95	263.40	6.25	10.35	8.70	10.55	188.26	189.39	189.39	0.99	1.00	0.99	1595
26-11-2016	19:30	49.97	407	410	409	0.50	2.10	2.20	2.30	266.50	240.50	260.90	9.75	11.50	9.60	9.35	167.16	188.39	188.39	0.99	0.99	0.99	1788
26-11-2016	20:00	49.89	409	412	412	0.55	2.20	2.35	2.50	271.70	222.25	272.55	13.00	11.40	11.10	10.85	160.52	181.97	181.97	0.99	0.99	0.99	1879
26-11-2016	20:30	49.91	414	417	417	0.55	2.30	2.50	2.60	268.95	216.50	238.75	14.40	11.05	12.45	13.30	171.12	172.82	172.82	0.99	0.99	0.99	1954
26-11-2016	21:00	49.95	417	421	420	0.60	2.30	2.50	2.60	268.95	201.85	238.30	11.15	13.65	12.85	13.15	163.49	185.21	185.21	0.99	0.99	0.99	2046
26-11-2016	21:30	50.03	412	416	416	0.65	2.40	2.60	2.70	251.55	186.50	182.00	17.90	13.35	13.95	16.80	151.26	153.49	153.49	0.99	0.99	0.97	2122
26-11-2016	22:00	49.96	409	413	414	0.65	2.50	2.65	2.75	238.75	186.50	182.00	17.90	13.35	13.95	16.80	151.26	153.49	153.49	0.99	0.99	0.97	2193
26-11-2016	22:30	49.96	403	406	407	0.60	2.50	2.55	2.65	208.35	162.60	168.25	15.95	14.70	14.75	17.10	123.96	144.54	144.54	0.99	0.99	0.97	2255
26-11-2016	23:00	50.00	407	411	411	0.60	2.50	2.55	2.65	208.35	162.60	168.25	15.95	14.70	14.75	17.10	123.96	144.54	144.54	0.99	0.99	0.97	2255
26-11-2016	23:30	50.01	409	412	412	0.60	2.50	2.50	2.60	189.95	144.25	159.25	14.55	14.80	14.85	16.40	116.46	126.56	126.56	0.99	0.99	0.96	2317
27-11-2016	0:00	50.01	413	416	417	0.60	2.40	2.45	2.60	189.95	144.25	159.25	14.55	14.80	14.85	16.40	116.46	126.56	126.56	0.99	0.99	0.96	2317
27-11-2016	0:30	49.98	412	415	415	0.55	2.40	2.40	2.50	181.55	140.65	144.30	12.65	15.60	14.40	16.45	113.96	118.01	118.01	0.99	0.99	0.96	2375
27-11-2016	1:00	49.97	412	416	416	0.50	2.35	2.40	2.50	177.40	138.40	138.75	16.80	14.85	15.35	17.95	108.70	115.50	115.50	0.99	0.99	0.95	2432
27-11-2016	1:30	50.00	415	418	418	0.50	2.30	2.40	2.40	178.30	134.15	137.85	18.80	14.70	15.55	18.05	105.61	108.32	108.32	0.99	0.99	0.96	2539
27-11-2016	2:00	50.00	418	421	421	0.50	2.30	2.40	2.40	157.35	124.75	127.45	19.75	14.20	16.10	18.70	98.69	108.46	108.46	0.99	0.99	0.96	2592
27-11-2016	2:30	50.02	416	419	419	0.50	2.15	2.25	2.30	150.65	119.00	116.75	16.95	14.50	15.35	18.65	91.23	101.73	101.73	0.99	0.97	0.94	2641
27-11-2016	3:00	50.03	420	423	423	0.50	2.10	2.20	2.30	137.40	111.30	110.20	14.95	14.15	14.20	17.70	86.00	93.16	93.16	0.99	0.99	0.96	2687
27-11-2016	3:30	50.00	420	422	423	0.50	2.10	2.20	2.30	134.90	108.50	106.70	15.60	14.60	15.00	18.75	83.99	87.44	87.44	0.99	0.99	0.97	2730
27-11-2016	4:00	49.99	419	422	422	0.50	2.10	2.20	2.30	137.10	107.35	107.55	16.85	14.30	15.90	18.75	84.10	85.20	85.20	0.99	0.99	0.97	2772
27-11-2016	4:30	49.98	414	419	419	0.50	2.05	2.15	2.20	135.80	111.85	108.00	15.20	14.55	15.20	18.95	83.92	85.37	85.37	0.99	0.99	0.97	2814
27-11-2016	5:00	50.01	415	417	417	0.40	2.00	2.10	2.20	141.50	114.70	113.05	15.90	13.60	14.60	17.95	86.78	88.08	88.08	0.99	0.99	0.98	2894
27-11-2016	5:30	49.99	410	413	413	0.40	2.00	2.10	2.20	142.25	118.50	113.40	14.65	13.25	14.00	16.85	87.36	88.55	88.55	0.99	0.99	0.98	2943
27-11-2016	6:00	49.99	413	416	416	0.45	1.90	2.00	2.05	126.90	108.05	115.85	11.05	12.00	12.65	14.80	83.16	84.18	84.18	0.99	0.99	0.96	2984
27-11-2016	6:30	49.99	417	420	420	0.50	1.90	2.00	2.00	146.30	121.55	143.05	11.70	10.25	11.25	12.00	99.05	99.83	99.83	0.99	0.99	0.99	3034
27-11-2016	7:00	49.96	416	420	419	0.50	1.85	1.90	1.95	156.70	126.45	160.80	16.90	9.30	10.55	9.25	111.41	112.13	112.13	0.99	0.99	0.99	3085
27-11-2016	7:30	49.91	415	416	418	0.50	1.90	1.95	2.00	147.85	113.20	168.80	20.95	10.30	12.20	10.40	102.79	103.50	103.50	0.99	0.99	0.99	3141
27-11-2016	8:00	49.97	414	418	418	0.55	1.90	2.00	2.00	173.98	139.70	147.80	12.95	9.05	10.10	12.45	110.29	111.09	111.09	1.00	0.99	0.99	3196
27-11-2016	8:30	49.96	416	419	419	0.60	1.90	2.00	2.00	162.90	128.75	165.85	19.35	8.35	10.75	10.95	114.60	115.32	115.32	1.00	0.99	0.99	3253
27-11-2016	9:00	49.99	412	416	416	0.60	1.90	1.90	1.95	202.50	136.85	195.65	20.75	7.30	9.65	9.55	125.76	126.41	126.41	1.00	0.99	0.99	3316
27-11-2016	9:30	49.95	411	414	414	0.55	1.90	2.00	2.00	211.80	174.90	216.65	12.95	7.25	8.65	8.20	143.35	143.83	143.83	1.00	0.99	0.99	3388
27-11-2016	10:00	49.95	409	412	413	0.50	1.95	2.00	2.05	206.65	179.25	187.75	8.10	7.55	7.95	9.70	135.68	136.42	136.42	1.00	0.99	0.99	3456
27-11-2016	10:30	49.93	406	409	412	0.40	1.95	2.05	2.15	171.25	165.15	165.00	2.45	9.55	8.75	11.35	117.34	118.17	118.17	0.99	0.99	0.99	3514
27-11-2016	11:00	49.94	405	407	408	0.50	2.10	2.10	2.10	194.00	174.50	194.00	6.90	8.85	8.70	9.70	131.41	132.13	132.13	1.00	0.99	0.99	3560
27-11-2016	11:30	49.93	404	406	407	0.55	2.10	2.15	2.20	188.00	149.15	156.65	13.45	8.15	8.90	12.20	114.39	115.25	115.25	1.00	0.99	0.99	3637

TERI Report No. 2016/815

Date	Time	Hz	Voltage (V)			Vunb	%Vind			Current (A)			Aunb	%kWhd			LW	KVA		PF		kWh	
			L1	L2	L3		%	L1	L2	L3	L1	L2		L3	L1	L2		L3	Sum	Sum	L1		L2
27-11-2016	12:00	49.99	408	411	412	0.45	2.05	2.10	2.20	159.85	152.45	137.50	8.85	10.25	9.35	13.60	165.57	10.95	105.51	0.99	0.99	0.99	3590
27-11-2016	12:30	49.95	407	409	410	0.40	2.00	2.00	2.05	152.90	147.85	144.90	6.25	10.30	9.55	12.30	104.12	14.37	105.25	0.99	0.99	0.99	3742
27-11-2016	13:00	50.01	410	412	413	0.50	2.05	2.05	2.05	149.75	139.95	161.25	4.85	11.05	10.75	12.20	103.85	9.49	104.87	0.99	0.99	0.99	3794
27-11-2016	13:30	50.01	413	415	416	0.50	2.10	2.10	2.20	152.15	122.80	142.60	11.75	10.65	12.05	12.90	99.11	10.68	100.04	0.99	0.99	0.99	3844
27-11-2016	14:00	50.01	415	418	418	0.50	2.20	2.20	2.25	163.60	125.15	157.40	13.90	11.60	12.90	12.45	104.07	4.47	105.06	0.99	0.99	0.99	3886
27-11-2016	14:30	49.98	413	416	416	0.50	2.25	2.25	2.30	161.80	130.50	164.80	14.35	11.50	12.65	12.40	108.58	3.74	108.52	0.99	0.99	0.99	3950
27-11-2016	15:00	50.00	416	419	419	0.50	2.05	2.10	2.15	144.70	120.10	144.45	11.95	11.90	12.45	13.10	97.85	5.88	98.80	0.99	0.99	0.99	3999
27-11-2016	16:30	49.90	418	419	419	0.50	2.20	2.20	2.30	144.15	120.10	122.45	11.85	12.00	12.00	15.35	92.33	11.86	93.34	0.99	0.99	0.99	4045
27-11-2016	16:30	49.95	417	420	420	0.50	2.15	2.20	2.20	156.35	124.40	147.95	13.10	10.70	11.40	12.55	102.83	7.77	103.75	0.99	0.99	0.99	4096
27-11-2016	16:30	49.97	415	419	419	0.50	2.15	2.20	2.25	146.30	116.15	147.40	15.70	11.45	12.45	12.70	98.86	0.53	98.79	0.99	0.99	0.99	4146
27-11-2016	17:00	50.03	415	418	419	0.50	2.10	2.20	2.20	151.20	124.95	137.95	11.35	11.80	12.10	14.15	98.88	0.03	99.08	0.99	0.99	0.99	4199
27-11-2016	17:30	50.02	413	418	417	0.50	2.10	2.20	2.25	177.45	168.35	178.25	4.20	11.30	10.20	12.50	124.62	0.70	125.70	0.99	0.99	0.99	4258
27-11-2016	18:00	50.07	411	415	416	0.60	2.25	2.35	2.50	225.25	203.16	201.85	7.05	12.15	11.15	13.85	145.18	-5.44	150.88	0.99	0.99	0.99	4332
27-11-2016	18:30	50.03	409	413	412	0.60	2.40	2.60	2.75	274.15	232.30	246.45	9.20	12.50	11.95	14.35	177.05	4.11	178.75	0.99	0.99	0.99	4421
27-11-2016	19:00	50.04	412	415	415	0.50	2.40	2.55	2.65	311.00	259.20	277.05	10.30	10.15	10.05	11.80	201.03	5.43	202.49	0.99	0.99	0.99	4521
27-11-2016	19:30	50.01	413	418	416	0.50	2.40	2.55	2.65	313.20	274.40	296.70	8.85	10.10	9.40	10.75	210.49	3.08	211.92	0.99	1.00	0.99	4636
27-11-2016	20:00	50.01	415	419	418	0.60	2.40	2.65	2.70	304.45	255.25	256.25	11.80	10.40	10.25	13.15	196.14	6.80	196.52	0.99	0.99	0.99	4724
27-11-2016	20:30	49.99	415	419	418	0.65	2.40	2.70	2.70	299.05	229.95	236.70	13.30	10.85	11.55	12.30	189.93	8.91	191.79	0.99	0.99	0.99	4819
27-11-2016	21:00	50.03	417	421	421	0.60	2.45	2.70	2.75	282.50	206.00	215.20	12.45	13.35	12.75	15.70	161.11	-5.72	163.25	0.99	0.99	0.99	4900
27-11-2016	21:30	50.01	419	422	423	0.60	2.45	2.70	2.70	283.06	196.25	189.85	18.95	12.80	14.15	18.05	152.84	-9.46	155.17	0.99	0.99	0.99	4976
27-11-2016	22:00	50.05	412	415	415	0.60	2.55	2.70	2.80	228.05	178.75	189.15	14.75	14.70	15.45	17.45	140.03	-19.13	142.59	0.99	0.99	0.99	5046
27-11-2016	22:30	49.99	405	408	408	0.55	2.55	2.60	2.75	207.45	161.85	163.30	16.85	15.00	15.30	17.80	123.11	-10.82	125.23	0.99	0.99	0.99	5108
27-11-2016	23:00	50.00	410	414	414	0.50	2.45	2.55	2.65	156.45	157.75	155.90	15.55	15.25	15.05	17.90	119.15	-11.73	121.38	0.99	0.99	0.99	5167
27-11-2016	23:30	50.02	413	416	416	0.60	2.40	2.50	2.60	188.20	153.05	156.55	13.40	15.60	15.45	17.05	117.05	-17.51	119.41	0.99	0.99	0.99	5228
Average/Total	49:28	49:5	408	409	409	0.52	2.12	2.20	2.22	193.90	161.25	172.80	13.75	11.63	11.93	13.69	124.42	-3.16	125.81	0.99	0.99	0.99	5266
Maximum	50:01	413	416	416	416	0.56	2.40	2.55	2.65	313	274	297	6.95	10.1	9.4	10.8	210	3	212	0.99	1.00	0.99	5226
Minimum	0:00	0	0	0	0	0.00	0.00	0.00	0.00	0	0	0	0.00	0.0	0.0	0.0	0	0	0	0.00	0.00	0.00	0.00

Main DB Power distribution

Section/ Panel	Phase	Voltage (V)	Vind (%)	Current (A)	Athd (%)	KW	KVA	PF	KVAR	Hz
Mechanical Block + Girls Hostel	R	227	1.5	63.5	6.1	13.6	14.4	0.95	4.7	50
	Y	225	2	60.2	5.8	12.1	13.6	0.89	6.1	49.9
	B	227	1.5	61.4	7.5	12.3	13.9	0.88	6.6	49.9
Server Room	R	226	1.4	3.81	51	6.72	0.86	0.83	0.15	49.9
	Y	224	1.5	10.6	17.3	2.3	2.4	0.95	0.6	49.9
	B	227	2	3.84	54.4	0.71	0.87	0.81	0.17	50
SVN Block	R	227	1.7	48.7	6	10.9	11.3	0.96	2.9	49.9
	Y	224	1.5	31.6	2.1	5.6	7.1	0.79	4.4	50
	B	227	1.4	57.6	2.1	12.9	13.1	0.98	2.5	50
HK Block	R	226	1.6	12.9	14.3	2.7	2.9	0.94	1.9	49.9
	Y	224	1.6	11.3	32.2	2.3	2.5	0.89	0.8	49.9
	B	226	1.6	5.42	33.5	0.62	1.23	0.51	0.98	49.9
Library Block	R	226	1.5	21.3	18.5	4.1	4.8	0.86	2.4	49.9
	Y	225	2	17.1	23.9	3.6	3.8	0.93	1	49.9
	B	227	1.7	19.2	25.4	4.1	4.3	0.95	1.9	50
SBS Block	R	226	1.6	11.5	22.2	2.4	2.8	0.94	0.7	49.9
	Y	224	2	13.5	16.2	3	3	0.98	0.4	50
	B	226	1.8	15.7	14	3.5	3.8	0.99	1	50
CS Block	R	225	1.5	50.3	15.1	10.9	11.3	0.96	2.7	49.9
	Y	224	2	89.4	8.2	19.8	20	0.99	1.7	50
	B	226	1.8	72.3	10	16.2	16.3	0.99	0.8	49.9
Bank Block	R	225	1.7	18.4	17.1	4.1	4.1	0.99	0.1	49.9
	Y	224	2	12.4	10.7	2.7	2.8	0.99	0.3	50
	B	226	1.7	5.28	14.7	1.18	1.19	0.96	0.13	50
SCB Block	R	226	1.6	42.9	7.5	8.5	9.7	0.92	3.6	50
	Y	224	1.9	52.8	10.4	10.3	11.8	0.87	6.7	50
	B	226	1.5	52.7	9.4	11	11.9	0.92	4.4	50
SMV Block	R	226	1.3	29	8.4	6	6.5	0.92	2.6	50
	Y	225	1.5	9	21.4	2	2	0.98	0.1	50
	B	226	1.9	37	6.5	8.2	8.4	0.99	1.1	50

Blockwise Power distribution

Blockwise Power distribution											
Section/ Panel	Phase	Voltage (V)	Vlhd (%)	Current (A)	Aflhd (%)	kW	kVA	PF	KVAr	Hz	Remarks
HK Building											
UPS- 20kVA	3Ø	393	1.7	1.82	111.3	0.79	1.24	0.64	0.13	50	N-E :5V-10V
UPS-3kVA	3Ø										
No Load											
Building AC	1Ø	231	3.3	8.54	21.1	1.91	1.98	0.97	0.26	50	
LD9 + RPDB	R	226	1.2	7.55	7.1	1.69	1.71	0.99	0.18	50.1	
	Y	229	1.4	6.53	10.2	1.35	1.5	0.9	0.64	50	
	B										
No Load											
Chhatrapati Shiwaji Block (CS Block)											
Sub Panel A	R	226	2.4	6.39	33.4	1.36	1.45	0.94	0.12	49.7	N-E :0.4V
	Y	224	3	8.64	8.5	1.82	1.94	0.94	0.63	50	
	B	225	2.7	4.9	15.4	1.01	1.1	0.92	0.39	50	
Sub Panel B	R	225	2.2	43.6	15	9.5	9.8	0.97	1.9	50	
	Y	223	2	25.6	13.8	5.6	5.7	0.99	0.5	50	
	B	225	2.7	56.4	12.1	12.3	12.7	0.97	2.5	50	
Sub Panel C	R	224	2.3	5.82	22.3	1.09	1.3	0.84	0.65	50	
	Y	224	2.1	7.29	18.4	1.6	1.63	0.98	0.18	50	
	B	226	2.6	2.29	24.9	0.49	0.52	0.95	0.1	50	
Netaji Subhas Chandra Bose Block (NSCB Block)											
Feeder 1	R	227	1.4	8.55	2.5	1.72	1.94	0.89	0.87	50	N-E :0.3V
	Y	226	2.6	8.48	3.1	1.69	1.91	0.88	0.92	50	
	B	226	2.5	8.64	2.9	1.75	1.95	0.9	0.86	50	
Feeder 4	R	227	1.5	2.91	11.8	0.49	0.66	0.74	0.44	50	
	Y	225	2.2	3.25	58.1	0.56	0.73	1	0.05	50	
	B	225	0								
Feeder 7	B	226	2.5	5.09	8.8	0.89	1.15	0.77	0.71	49.9	
Feeder-10	R	227	1.8	9.24	22.4	2	2.1	0.97	0.2	50	
	Y	226	2	18	9.4	3.5	4.1	0.88	2	50	
	B	226	2.1	13.8	20.6	3	3.1	0.98	0	50	
F11- UPS	3Ø	393	1.9	5.24	36.8	2.8	3.5	0.8	1.8	50	
F12- UPS	3Ø	393	1.8	3.97	96.5	1.66	2.7	0.62	0.86	50	
F15- UPS Main	R	228	1.4	6.63	21.2	1.1	1.51	0.73	0.96	50	
	Y	226	2.6	3.92	26	0.79	0.9	0.88	0.35	50	
	B	225	2.5	7.27	20.4	1.34	1.64	0.82	0.85	50	
Mechanical Block + Girls Hostel											
Canteen	R	224	2.5	17.4	8.6	3.5	3.9	0.9	1.7	50	
	Y	224	2.6	6.7	12	1.14	1.5	0.76	0.96	50	
	B	225	2.2	11.56	7.6	2.6	2.6	0.99	0.2	50	
Ladies Hostel 2	R	223	2.5	6.64	9.1	1.47	1.48	0.99	0.02	50	
	Y	223	2.5	3.01	7.9	0.63	0.67	0.94	0.23	50	
	B	223	2.9	7.53	8.3	1.67	1.68	1	0.02	50	

Sheet 2 of 3

Mech. Block C/G	R	225	2.5	19.2	12.4	3.6	4.3	0.82	2.4	50	N-E: 0.4V
	Y	223	2.6	20.6	10.2	4.1	4.6	0.9	2	50	
	B	224	2.9	21.5	10.8	4	4.8	0.84	2.6	50	
To Basic Sci. LD8	R	225	0								
	Y	222	2.4	9.99	11.5	1.44	2.22	0.65	1.69	50	
	B	224	2.2	3.06	7.5	0.68	0.69	1	0.01	50	
To Ladies Hostel 1	R	224	2.4	14.5	9.5	3	3.3	0.93	1.1	50	
	Y	223	2.5	14.6	3.1	3	3.3	0.93	1.2	50	
	B	226	2.4	16.9	8.3	3.6	3.8	0.94	1.3	50	
Mechanical Block											
F4 UPS	3Ø	390	2.2	5.06	66.2	2.65	3.41	0.78	0.96	49.9	N-E: 0.4V
STP	3Ø	389	1.8	11.1	6.5	6.876	7.534	0.91	3.064	0.91	
F12	R	225	2.4	1.59	10.2	0.25	0.36	0.71	0.25	49.9	
	Y	225	0	0							
	B	226	2.3	3.31	12.2	0.66	0.75	0.9	0.32	50	
Library & Information Block											
Feeder 1	R	226	0								N-E: 5V
	Y	226	2.3	2.48	77	0.36	0.56	0.64	0.01	50	
	B	230	2.2	3.2	65.5	0.53	0.74	0.72	0.15	50	
Feeder 3 UPS 15kVA	3Ø	394	1.3	5.26	45	3.26	3.59	0.91	0.01	50	
Feeder 4 10kVA	R	228	2	2.89	52	0.2	0.61	0.32	0.47	50	
	Y	225	2.4	2.72	52.3	0.23	0.61	0.38	0.46	50	
	B	229	2.4	2.89	53.2	0.52	0.66	0.79	0.17	50	
Auditorium Total - DG Supply	3Ø	387	1.2	99.7	2	58	67	0.87	32	50	
Stage AC	3Ø	388	1.6	25.5	3	13.8	17.1	0.81	10	50.5	
Auditorium AC	3Ø	388	1.5	58.5	2.4	32.9	39.3	0.84	21.8	50	
Stage Lighting	3Ø	386	1.5	10.6	49.6	5.93	7.08	0.84	2.13	50	Only LED Load

Electrical Drives

Measured power parameters of Electrical Drives

Sl No	Block	Motor Description	Motor Rating		Motor Operating Parameters							% Loading	Remarks
			kW	EM(%)	V	V _{line} (%)	A	AltHd (%)	kW	kVA	PF	kVar	Hz
1	HK	Overhead Tank Pump	2.2	78.00%	380	1.41	3.25	3.80	1.71	2.20	0.81	1.98	50.00
		AC II 4TR			391	2.20	7.10	4.40	4.26	4.85	0.88	2.18	50.00
		AC I 4TR			391	1.50	7.22	3.10	4.24	4.89	0.87	2.46	50.00
2	SW	Pump for solar system	2.2	70.00%	387	1.00	5.05	3.05	2.42	3.38	0.72	2.34	50.00
3		Overhead Tank Pump	2.2	78.00%	390	1.20	3.70	3.60	2.12	2.50	0.80	1.34	49.90
4		Cooler 1st Floor			271	-	1.68	-	0.26	0.37	0.89	0.28	50.00
5	NSCB	Cooler 2nd Floor			203	-	1.50	-	0.20	0.54	0.59	0.27	50.00
6		MachBlock pump	2.2	78.00%	388	1.00	5.00	2.40	2.87	3.42	0.84	1.83	50.00
7		Submersible pump-1	2.2	79.00%	388	1.70	6.61	2.70	3.39	4.44	0.75	2.90	50.00
8	CS Block	Submersible pump-2	2.2	79.00%	390	1.50	4.64	3.30	2.57	3.14	0.82	1.74	50.00
9		Overhead Tank Pump-1	7.5	88.00%	389	1.10	13.62	2.10	7.90	9.23	0.86	4.60	50.00
10		Overhead Tank Pump-2	7.5	88.00%	386	1.20	14.70	1.10	8.80	9.83	0.89	4.30	49.90
11	CS Block	Water Cooler (Vollas)	1.55		209	-	5.88	-	1.18	1.19	0.99	0.02	50.00
12		Water cooler A block (Vollas)	1.55		209	-	6.08	-	1.29	1.30	0.99	0.02	50.00
		URV III			304	2.30	5.30	75.80	2.87	3.66	0.79	0.50	50.00
13	CS Block	Blower	0.7	82.00%	370	2.10	3.27	3.80	1.52	2.00	0.72	1.42	49.90
14		Waste transfer pump	1.5	78.00%	387	2.20	2.01	5.00	0.99	1.29	0.44	1.14	50.00
15		Water Cooler			209	-	1.58	-	0.26	0.35	0.74	0.24	50.00
16	CS Block	Submersible pump	1.7	80.00%	372	2.20	6.98	2.30	3.98	4.46	0.89	2.01	50.00
17		Kitchen			372	2.20	3.60	3.20	1.89	2.36	0.80	1.43	50.00
18		Odour I	3		219	2.00	7.95	2.60	1.72	1.72	1.00	0.20	50.00
19	CS Block	Submersible pump	2.2	79.00%	371	1.50	5.88	3.40	3.17	3.76	0.84	2.06	50.00
20		Dye water pump	0.74	72.00%	208	-	2.98	-	0.58	0.61	0.94	0.19	50.00

311	Coiler	202 -	1.73 -	0.26	0.30	0.71	0.26	50.00					
312	Submersible pump	2.2	70.00%	365	1.50	7.81	1.80	4.32	5.20	0.83	2.39	80.00	155%
313	Monoblock pump	2.2	79.00%	386	1.50	4.42	5.10	2.53	2.96	0.66	1.49	53.10	91%
314	Hot water pump	3.7	82.00%	364	2.00	7.60	2.40	4.20	5.10	0.84	2.80	50.00	93%
315	Screw water pump	3.7	82.00%	383	2.30	9.15	2.50	5.30	6.12	0.87	3.10	50.00	117%
316	Crushing water pump	2.2	79.00%	385	2.20	4.61	4.80	2.61	3.03	0.60	1.04	50.00	94%
317	Filter Pump I	2.2	79.00%	365	1.50	3.80	4.60	2.10	2.53	0.83	1.41	50.00	75%
318	Filter Pump II	2.2	79.00%	384	2.00	3.38	4.30	2.02	2.25	0.95	0.98	50.00	73%
319	Transfer Pump	3.7	82.00%	376	2.00	7.52	3.50	4.27	4.98	0.67	2.35	40.80	95%
320	Blower II	7.5	85.00%	381	2.00	15.00	5.10	8.60	9.98	0.87	4.90	50.00	99%
321	Distribution Pump (10bars)	1.5	85.50%	389	1.70	2.34	6.50	1.26	1.57	0.81	0.91	40.50	72%
322	Distribution Pump (20bars)			384	1.50	6.08	3.30	3.23	4.04	0.80	2.44	45.80	
323	Says AC			383	1.00	25.50	3.00	13.80	17.10	0.81	10.00	50.00	Unload
324	Auditorium AC			388	1.50	58.50	2.40	32.90	39.30	0.84	21.80	50.00	Load
325	Pump (20)			373	1.40	6.08	3.00	4.50	5.63	0.81	3.20	50.00	
326	Pump (10)	2.2	79.00%	382	2.10	4.08	4.80	2.69	2.75	0.75	1.88	50.00	75%
327	Blower+ Heater			376	1.50	6.01	2.70	3.77	3.52	0.96	1.60	50.00	
328	Roller			376	2.00	1.30	2.80	0.31	0.84	0.36	0.78	50.00	
329	Coiler (Valtas)	1.55		269 -		5.84 -		1.19	1.25	0.99	0.23	50.00	
330	Library Hall AC 3TR			405	1.05	3.96	5.50	2.20	2.71	0.81	1.58	45.00	
331	Library Hall AC 4TR			369	2.20	5.73	10.30	3.44	3.96	0.97	1.98	50	

Measured Load Parameters of STP

Date	Time	Hr	kVrms	kVthd	Arms	Athd	Power			PF	kWh
							kW	kVA	kVA		
24-11-2016	11:00	50.01	379	1.40	26.00	4.00	15.27	7.74	17.12	0.89	1.27
24-11-2016	11:05	50.04	379	1.40	26.10	4.00	15.26	7.86	17.17	0.89	1.54
24-11-2016	11:10	49.96	377	1.50	26.50	4.00	15.41	7.97	17.35	0.89	1.83
24-11-2016	11:15	49.90	375	1.30	28.70	3.60	16.72	8.39	18.71	0.89	5.22
24-11-2016	11:20	49.93	375	1.30	28.60	3.60	16.67	8.33	18.63	0.89	6.61
24-11-2016	11:25	50.02	378	1.40	26.20	3.80	15.69	6.80	17.15	0.92	7.92
24-11-2016	11:30	50.06	378	1.40	31.50	3.80	18.77	8.63	20.66	0.91	9.48
24-11-2016	11:35	50.04	379	1.40	31.00	3.80	18.48	8.60	20.38	0.91	11.02
24-11-2016	11:40	49.99	378	1.50	30.30	3.80	18.01	8.57	19.86	0.91	12.52
24-11-2016	11:45	49.99	379	1.60	27.70	4.00	16.68	7.32	18.22	0.92	13.91
24-11-2016	11:50	50.00	376	1.50	26.90	3.90	16.20	6.76	17.55	0.92	15.26
24-11-2016	11:55	49.99	377	1.50	26.10	4.00	15.71	6.60	17.05	0.92	16.57
24-11-2016	12:00	50.00	377	1.50	26.40	4.00	15.85	6.87	17.28	0.92	17.89
24-11-2016	12:05	50.06	381	1.50	12.50	3.00	7.58	3.13	8.21	0.00	18.52
24-11-2016	12:10	50.05	382	1.60	6.90	2.30	4.25	1.68	4.57	0.00	18.88
24-11-2016	12:15	49.92	382	1.50	7.40	2.99	4.57	1.80	4.96	0.00	19.26
24-11-2016	12:20	49.80	380	1.50	7.80	3.30	4.74	2.05	5.19	0.00	19.65
24-11-2016	12:25	49.86	380	1.50	6.40	2.70	3.89	1.64	4.23	0.00	19.96
24-11-2016	12:30	49.96	382	1.40	4.60	1.80	2.87	1.16	3.10	0.00	20.22
24-11-2016	12:35	50.07	385	1.40	5.40	2.30	3.36	1.39	3.65	0.00	20.50
24-11-2016	12:40	49.97	386	1.40	4.20	1.80	2.58	1.22	2.86	0.00	20.71
24-11-2016	12:45	49.95	388	1.50	4.30	1.90	2.71	1.09	2.93	0.00	20.94
24-11-2016	12:50	49.97	386	1.50	4.50	1.90	2.79	1.16	3.03	0.00	21.17
24-11-2016	12:55	49.99	388	1.70	3.90	1.80	2.42	1.09	2.67	0.00	21.37
24-11-2016	13:00	50.00	389	1.50	4.30	1.70	2.60	1.32	2.91	0.00	21.59
24-11-2016	13:05	50.05	392	1.50	5.40	2.10	3.22	1.74	3.67	0.00	21.86
24-11-2016	13:10	50.12	396	1.60	5.90	2.40	3.70	1.74	4.00	0.00	22.17
24-11-2016	13:15	50.04	395	1.60	2.90	1.20	1.85	0.88	2.05	0.00	22.32
24-11-2016	13:20	49.94	395	1.60	0.70	0.30	0.44	0.21	0.49	0.00	22.36
24-11-2016	13:25	50.03	398	1.60	0.60	0.30	0.42	0.20	0.47	0.00	22.39
24-11-2016	13:30	50.08	402	1.70	0.40	0.20	0.30	0.16	0.34	0.00	22.42
24-11-2016	13:35	50.02	403	1.70	1.00	0.40	0.62	0.32	0.70	0.00	22.47
24-11-2016	13:40	49.98	403	1.70	0.00	0.00	0.00	0.00	0.00	0.00	22.47
24-11-2016	13:45	49.98	401	1.70	0.30	0.10	0.21	0.11	0.24	0.00	22.48
24-11-2016	13:50	50.01	401	1.70	1.50	0.70	0.96	0.50	1.09	0.00	22.57
24-11-2016	13:55	49.95	402	1.70	1.10	0.60	0.70	0.35	0.79	0.00	22.63
24-11-2016	14:00	49.93	401	1.90	0.40	0.20	0.31	0.15	0.34	0.00	22.65
24-11-2016	14:05	50.01	396	1.90	0.50	0.20	0.30	0.15	0.34	0.00	22.68
24-11-2016	14:10	50.02	395	1.90	0.50	0.30	0.36	0.18	0.41	0.00	22.71
24-11-2016	14:15	49.90	396	2.00	1.90	1.00	1.20	0.62	1.36	0.00	22.81
24-11-2016	14:20	49.85	396	1.90	4.40	2.20	2.70	1.34	3.02	0.00	23.03
24-11-2016	14:25	49.88	394	1.90	0.60	0.30	0.40	0.19	0.45	0.00	23.07
24-11-2016	14:30	49.98	395	2.00	1.50	1.00	0.93	0.45	1.03	0.00	23.14
24-11-2016	14:35	49.98	395	1.80	4.60	2.30	2.86	1.33	3.16	0.00	23.38
24-11-2016	14:40	49.92	391	1.90	8.50	4.70	5.34	2.27	5.80	0.00	23.83
24-11-2016	14:45	49.96	390	2.00	9.00	7.60	5.60	2.43	6.11	0.00	24.29
24-11-2016	14:50	50.02	389	1.80	10.30	7.20	6.40	2.79	6.99	0.00	24.82
24-11-2016	14:55	49.98	389	1.60	11.30	6.50	6.88	3.06	7.53	0.91	25.40
24-11-2016	15:00	49.92	388	1.90	13.80	5.50	8.41	3.95	9.31	0.91	26.10
24-11-2016	15:05	49.98	389	1.80	13.70	5.40	8.41	3.78	9.23	0.91	26.80
24-11-2016	15:10	50.02	389	1.70	15.30	5.00	9.32	4.36	10.30	0.91	27.58
24-11-2016	15:15	49.94	386	1.80	17.10	4.80	10.26	5.20	11.50	0.89	28.43
24-11-2016	15:20	49.92	386	1.80	15.60	5.00	9.40	4.61	10.47	0.90	29.21
24-11-2016	15:25	49.92	384	1.70	16.40	4.60	9.75	4.84	10.93	0.90	30.03
24-11-2016	15:30	49.85	382	1.80	17.20	4.80	10.24	5.04	11.41	0.90	30.88
24-11-2016	15:35	49.87	383	1.70	17.00	4.80	10.17	4.91	11.30	0.90	31.73
24-11-2016	15:40	49.84	385	1.70	17.00	4.70	10.17	5.07	11.37	0.90	32.58
24-11-2016	15:45	49.82	385	1.70	14.90	5.10	8.95	4.42	9.98	0.90	33.32

TERI Report No. 2016R815

Date	Time	Hz	kVrms	%Vthd	Arms	%Asth	Power			PF	kWh
							kW	kVA	kVA		
24-11-2016	15:50	49.88	384	1.90	11.40	6.40	6.75	3.38	7.58	0.89	33.89
24-11-2016	15:55	49.86	383	1.80	10.80	5.40	6.80	2.42	7.22	0.94	34.45
24-11-2016	16:00	49.85	383	1.70	7.60	1.30	1.52	0.54	1.61	0.00	34.58
24-11-2016	16:05	49.99	385	1.70	0.40	0.20	0.27	0.13	0.31	0.00	34.60
24-11-2016	16:10	50.01	386	1.90	8.80	4.60	5.15	2.84	5.90	0.00	35.03
24-11-2016	16:15	—	376	0.10	12.30	0.10	7.47	0.00	8.20	0.00	35.65
24-11-2016	16:20	49.99	403	2.40	12.80	4.70	8.10	3.88	8.98	0.90	36.33
24-11-2016	16:25	49.98	403	2.00	13.20	4.10	8.35	3.91	9.23	0.91	37.03
24-11-2016	16:30	49.99	403	2.00	13.30	4.10	8.38	4.00	9.29	0.90	37.71
24-11-2016	16:35	49.98	402	2.20	13.00	4.40	8.17	3.95	9.08	0.90	38.41
24-11-2016	16:40	49.98	400	2.20	13.00	4.30	8.26	3.65	9.03	0.92	39.09
24-11-2016	16:45	49.98	420	2.10	13.10	4.10	8.29	3.71	9.08	0.91	39.78
24-11-2016	16:50	49.98	400	1.90	13.30	3.60	8.38	3.80	9.24	0.91	40.48
24-11-2016	16:55	49.99	401	1.90	13.80	3.50	8.66	4.20	9.63	0.90	41.20
24-11-2016	17:00	49.99	402	1.70	14.10	3.20	8.83	4.42	9.88	0.90	41.94
24-11-2016	17:05	49.99	402	1.50	14.00	2.90	8.73	4.40	9.78	0.89	42.67
24-11-2016	17:10	—	386	0.30	13.90	0.50	8.49	0.00	9.60	0.00	43.38
24-11-2016	17:15	49.90	385	1.70	27.50	3.40	16.25	8.56	18.37	0.88	44.73
24-11-2016	17:20	49.93	385	1.60	26.00	3.40	15.48	7.95	17.40	0.89	46.02
24-11-2016	17:25	50.00	386	1.50	20.50	3.40	12.26	6.12	13.75	0.89	47.04
24-11-2016	17:30	49.95	385	1.50	20.40	3.20	12.20	6.19	13.68	0.89	48.06
24-11-2016	17:35	50.07	385	1.40	26.70	3.00	15.93	8.05	17.85	0.89	49.39
24-11-2016	17:40	50.08	384	1.30	28.00	2.80	16.69	8.40	18.68	0.89	50.78
24-11-2016	17:45	49.93	382	1.30	27.00	2.70	16.57	8.32	18.54	0.89	52.16
24-11-2016	17:50	49.95	381	1.30	28.10	2.70	16.62	8.30	18.58	0.89	53.54
24-11-2016	17:55	49.92	383	1.40	22.80	3.20	13.54	6.56	15.14	0.90	54.68
24-11-2016	18:00	49.90	383	1.40	19.60	3.30	11.79	5.47	13.00	0.91	55.66
24-11-2016	18:05	50.15	391	1.40	15.00	3.80	9.51	3.71	10.21	0.93	56.45
24-11-2016	18:10	50.04	396	1.40	14.30	3.80	9.15	3.59	9.83	0.93	57.22
24-11-2016	18:15	49.96	394	1.50	14.50	4.00	9.26	3.55	9.92	0.93	57.99
24-11-2016	18:20	49.99	392	1.50	14.30	4.00	9.15	3.38	9.76	0.94	58.75
24-11-2016	18:25	50.09	392	1.50	14.50	4.20	9.27	3.39	9.87	0.94	59.52
24-11-2016	18:30	50.80	392	1.50	14.20	4.10	9.06	3.37	9.67	0.94	60.28
24-11-2016	18:35	50.05	392	1.50	14.30	4.20	9.16	3.37	9.76	0.94	61.04
24-11-2016	18:40	50.07	392	1.50	14.50	4.40	9.28	3.37	9.87	0.94	61.81
24-11-2016	18:45	50.03	393	1.50	14.40	4.40	9.26	3.36	9.85	0.94	62.59
24-11-2016	18:50	50.03	393	1.50	14.40	4.50	9.28	3.36	9.87	0.94	63.36
24-11-2016	18:55	50.04	396	1.50	14.30	4.50	9.30	3.29	9.86	0.94	64.13
24-11-2016	19:00	50.03	397	1.60	13.60	4.70	8.71	3.37	9.38	0.00	64.86
24-11-2016	19:05	49.99	397	1.70	12.90	5.00	8.25	3.24	8.87	0.93	65.55
24-11-2016	19:10	49.99	397	1.70	12.50	5.20	8.00	3.29	8.62	0.93	66.21
24-11-2016	19:15	50.04	398	1.70	12.20	5.30	7.84	3.13	8.45	0.93	66.87
24-11-2016	19:20	50.02	398	1.70	12.10	5.20	7.82	3.04	8.39	0.93	67.52
24-11-2016	19:25	49.98	399	1.70	11.90	5.40	7.69	3.01	8.25	0.93	68.16
24-11-2016	19:30	50.02	399	1.70	11.70	5.50	7.60	2.92	8.14	0.93	68.79
24-11-2016	19:35	50.02	401	1.70	11.80	5.50	7.65	2.91	8.22	0.94	69.43
24-11-2016	19:40	49.97	403	1.70	11.70	5.60	7.67	2.90	8.20	0.94	70.07
24-11-2016	19:45	50.04	403	1.80	11.80	5.60	7.71	2.95	8.25	0.93	70.72
24-11-2016	19:50	50.03	406	1.80	11.50	5.70	7.54	2.96	8.10	0.93	71.34
24-11-2016	19:55	49.92	403	1.80	11.60	5.50	7.53	2.94	8.09	0.93	71.97
24-11-2016	20:00	50.00	402	1.80	11.70	5.40	7.58	3.01	8.16	0.93	72.60
24-11-2016	20:05	50.08	401	1.80	11.80	5.40	7.68	3.03	8.26	0.93	73.24
24-11-2016	20:10	50.05	401	1.80	11.90	5.50	7.71	3.06	8.30	0.93	73.89
24-11-2016	20:15	50.01	405	1.90	11.80	5.70	7.72	3.09	8.31	0.93	74.53
24-11-2016	20:20	49.94	405	1.90	11.70	5.80	7.58	3.24	8.25	0.92	75.16
24-11-2016	20:25	49.98	406	1.90	11.80	5.90	7.70	3.15	8.31	0.93	75.80
24-11-2016	20:30	50.06	407	2.00	11.70	6.00	7.67	3.16	8.29	0.92	76.44
24-11-2016	20:35	50.07	409	2.00	11.90	6.00	7.81	3.20	8.44	0.93	77.09
24-11-2016	20:40	49.93	409	2.00	12.00	6.10	7.90	3.21	8.53	0.93	77.75
24-11-2016	20:45	50.00	410	2.00	11.70	6.20	7.73	3.24	8.38	0.92	78.40

Date	Time	Hz	kVrms	V/Vthd	Arms	VAthd	Power			PF	kWh
							kW	kVar	kVA		
24-11-2016	20:50	50.08	411	2.00	11.80	6.20	7.77	3.14	8.42	0.92	79.04
24-11-2016	20:55	50.13	413	2.00	11.90	6.30	7.92	3.16	8.53	0.93	79.70
24-11-2016	21:00	50.13	413	2.00	11.80	6.30	7.89	3.15	8.49	0.93	80.36
24-11-2016	21:05	50.09	413	2.10	11.80	6.30	7.89	3.16	8.50	0.93	81.07
24-11-2016	21:10	49.96	405	2.10	11.80	5.70	7.78	3.01	8.34	0.93	81.67
24-11-2016	21:15	50.03	405	2.20	11.70	5.80	7.73	2.97	8.28	0.93	82.31
24-11-2016	21:20	50.11	408	2.20	11.70	6.00	7.76	2.93	8.30	0.94	82.96
24-11-2016	21:25	50.09	408	2.10	11.80	6.00	7.81	2.94	8.34	0.94	83.61
24-11-2016	21:30	50.04	409	1.10	11.70	6.00	7.77	2.91	8.30	0.94	84.25
24-11-2016	21:35	50.06	409	1.10	11.60	6.00	7.76	2.89	8.28	0.94	84.90
24-11-2016	21:40	50.13	411	1.10	11.60	6.10	7.74	3.00	8.31	0.93	85.55
24-11-2016	21:45	50.11	411	1.10	11.60	6.10	7.71	3.05	8.30	0.93	86.19
24-11-2016	21:50	50.06	412	1.10	11.50	6.20	7.65	3.11	8.26	0.93	86.83
24-11-2016	21:55	50.06	412	1.10	11.60	6.20	7.68	3.19	8.32	0.92	87.47
24-11-2016	22:00	50.10	413	1.10	11.70	6.20	7.78	3.23	8.43	0.92	88.12
24-11-2016	22:05	50.15	413	1.10	11.80	6.30	7.81	3.25	8.46	0.92	88.77
24-11-2016	22:10	49.98	404	1.30	12.20	5.20	7.97	3.19	8.59	0.93	89.43
24-11-2016	22:15	49.94	401	1.30	12.30	6.10	8.00	3.09	8.58	0.93	90.10
24-11-2016	22:20	50.01	402	1.30	12.40	6.10	8.12	3.08	8.68	0.93	90.78
24-11-2016	22:25	49.96	402	1.20	12.30	6.10	8.05	3.09	8.62	0.93	91.45
24-11-2016	22:30	50.01	404	1.20	12.30	6.20	8.10	3.10	8.67	0.93	92.12
24-11-2016	22:35	50.05	406	1.20	12.30	6.30	8.11	3.12	8.69	0.93	92.80
24-11-2016	22:40	49.98	407	1.20	12.20	6.40	8.05	3.15	8.64	0.93	93.47
24-11-2016	22:45	50.02	408	1.20	12.20	6.40	8.05	3.14	8.64	0.93	94.14
24-11-2016	22:50	50.04	409	1.20	12.10	6.50	8.03	3.15	8.62	0.93	94.81
24-11-2016	22:55	49.94	410	1.20	12.10	6.50	8.02	3.19	8.63	0.93	95.48
24-11-2016	23:00	49.99	410	1.20	12.00	6.60	7.96	3.18	8.57	0.93	96.14
24-11-2016	23:05	50.07	412	1.20	12.20	6.60	8.08	3.29	8.73	0.93	96.81
24-11-2016	23:10	50.02	413	1.20	12.10	6.70	8.02	3.39	8.70	0.92	97.48
24-11-2016	23:15	49.96	413	1.20	12.20	6.90	8.06	3.39	8.74	0.92	98.15
24-11-2016	23:20	49.97	414	1.20	11.90	6.90	7.85	3.38	8.55	0.92	98.81
24-11-2016	23:25	50.01	416	1.20	11.90	7.00	7.93	3.41	8.63	0.92	99.47
24-11-2016	23:30	50.06	417	1.20	11.90	7.00	7.93	3.43	8.64	0.92	100.13
24-11-2016	23:35	50.07	414	1.20	12.10	6.70	8.03	3.42	8.73	0.92	100.80
24-11-2016	23:40	50.01	413	1.20	12.00	6.90	7.94	3.35	8.62	0.92	101.46
24-11-2016	23:45	50.02	413	1.20	12.00	6.80	7.94	3.33	8.61	0.92	102.12
24-11-2016	23:50	50.07	414	1.20	12.10	6.70	8.01	3.39	8.70	0.92	102.79
24-11-2016	23:55	50.13	416	1.20	11.90	6.80	7.93	3.39	8.63	0.92	103.45
25-11-2016	0:00	50.13	416	1.20	12.00	6.90	8.02	3.38	8.70	0.92	104.12
25-11-2016	0:05	50.18	417	1.20	12.10	6.80	8.11	3.35	8.79	0.92	104.79
25-11-2016	0:10	50.15	416	1.20	12.30	6.70	8.24	3.40	8.91	0.92	105.48
25-11-2016	0:15	50.06	413	1.20	12.20	6.50	8.14	3.37	8.81	0.92	106.16
25-11-2016	0:20	50.07	409	1.20	12.60	6.10	8.31	3.34	8.96	0.93	106.85
25-11-2016	0:25	50.09	410	1.20	12.30	6.20	8.13	3.32	8.78	0.93	107.53
25-11-2016	0:30	50.08	410	1.20	12.10	6.20	7.98	3.30	8.63	0.92	108.19
25-11-2016	0:35	50.10	411	1.20	12.10	6.20	7.98	3.27	8.62	0.93	108.86
25-11-2016	0:40	50.07	411	1.20	12.30	6.10	8.15	3.32	8.81	0.93	109.54
25-11-2016	0:45	50.08	411	1.20	12.30	6.10	8.14	3.35	8.80	0.92	110.22
25-11-2016	0:50	50.05	411	1.20	12.40	6.10	8.22	3.31	8.88	0.93	110.90
25-11-2016	0:55	50.01	411	1.20	12.30	6.10	8.12	3.35	8.78	0.92	111.58
25-11-2016	1:00	50.01	411	1.20	12.10	6.10	8.00	3.33	8.66	0.92	112.24
25-11-2016	1:05	50.07	412	1.20	12.20	6.10	8.06	3.35	8.73	0.92	112.91
25-11-2016	1:10	50.04	412	1.20	12.00	6.10	7.95	3.35	8.63	0.92	113.58
25-11-2016	1:15	50.00	412	1.20	12.00	6.10	7.90	3.36	8.58	0.92	114.24
25-11-2016	1:20	49.99	414	1.20	11.90	6.20	7.89	3.36	8.57	0.92	114.89
25-11-2016	1:25	50.00	413	1.20	12.00	6.20	7.96	3.30	8.61	0.92	115.56
25-11-2016	1:30	50.03	415	1.20	11.90	6.30	7.88	3.34	8.56	0.92	116.21
25-11-2016	1:35	50.02	414	1.20	11.90	6.30	7.90	3.37	8.59	0.92	116.87
25-11-2016	1:40	50.00	415	1.20	11.90	6.20	7.88	3.34	8.55	0.92	117.53
25-11-2016	1:45	50.05	415	1.20	11.80	6.30	7.85	3.34	8.54	0.92	118.18

Date	Time	Hz	kVrms	%Vd	Arms	%Atd	Power			PF	kWh
							kW	kVA	kVA		
25-11-2016	1:50	50.05	416	2.20	11.90	6.30	7.91	1.17	8.60	0.92	118.84
25-11-2016	1:55	50.03	416	2.20	11.80	6.40	7.84	1.36	8.53	0.92	119.49
25-11-2016	2:00	50.05	418	2.30	10.10	5.70	6.72	1.89	7.31	0.00	120.05
25-11-2016	2:05	50.12	424	2.40	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	2:10	50.05	424	2.40	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	2:15	49.99	419	2.30	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	2:20	50.01	419	2.30	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	2:25	50.03	420	2.30	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	2:30	50.02	420	2.30	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	2:35	50.02	419	2.30	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	2:40	49.98	419	2.30	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	2:45	50.02	419	2.20	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	2:50	50.00	419	2.40	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	2:55	50.00	419	2.30	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	3:00	50.08	420	2.30	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	3:05	50.07	420	2.40	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	3:10	49.98	419	2.30	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	3:15	49.96	417	2.20	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	3:20	50.02	417	2.20	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	3:25	50.00	418	2.30	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	3:30	49.99	418	2.20	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	3:35	50.01	419	2.20	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	3:40	49.97	418	2.20	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	3:45	50.03	419	2.20	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	3:50	49.98	419	2.30	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	3:55	50.01	418	2.30	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	4:00	50.03	418	2.20	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	4:05	50.03	419	2.20	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	4:10	49.99	418	2.20	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	4:15	49.94	417	2.20	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	4:20	50.04	418	2.20	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	4:25	50.07	418	2.20	0.00	0.00	0.00	0.00	0.00	0.00	120.05
25-11-2016	4:30	50.02	417	2.20	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	4:35	50.02	416	2.20	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	4:40	50.02	415	2.20	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	4:45	49.98	414	2.30	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	4:50	50.02	414	2.30	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	4:55	50.04	413	2.20	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	5:00	50.03	412	2.20	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	5:05	50.06	410	2.20	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	5:10	50.05	409	2.20	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	5:15	49.92	407	2.20	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	5:20	49.95	406	2.20	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	5:25	49.93	405	2.20	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	5:30	49.94	404	2.20	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	5:35	50.07	403	2.00	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	5:40	50.01	403	2.00	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	5:45	49.95	403	2.00	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	5:50	49.93	400	2.00	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	5:55	49.94	399	2.00	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	6:00	49.94	397	1.80	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	6:05	50.11	404	1.80	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	6:10	50.13	413	1.80	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	6:15	49.97	411	1.70	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	6:20	50.02	409	1.70	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	6:25	50.03	405	1.70	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	6:30	49.93	400	1.60	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	6:35	50.07	397	1.60	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	6:40	50.00	392	1.60	0.00	0.00	0.00	0.00	0.00	0.00	120.06
25-11-2016	6:45	49.91	385	1.60	16.00	1.30	9.51	4.74	10.66	0.86	120.85

Date	Time	Hz	kVrms	kVbld	Arms	%Aibld	Power			PF	kWh
							kW	kVar	kVA		
25-11-2016	6:50	50.01	383	1.60	21.50	3.30	12.86	6.20	14.28	0.90	121.92
25-11-2016	6:55	49.99	390	1.50	21.40	3.20	12.65	6.25	14.11	0.90	122.97
25-11-2016	7:00	49.94	390	1.50	20.60	3.50	12.33	6.53	13.95	0.88	124.00
25-11-2016	7:05	49.98	391	1.30	20.40	3.30	12.25	6.51	13.87	0.88	125.02
25-11-2016	7:10	50.04	390	1.20	20.20	3.10	12.12	6.40	13.71	0.88	126.03
25-11-2016	7:15	49.93	390	1.30	20.30	3.10	12.11	6.49	13.74	0.88	127.04
25-11-2016	7:20	49.92	398	1.20	20.00	3.30	12.11	6.64	13.81	0.88	128.05
25-11-2016	7:25	49.92	398	1.20	22.00	3.30	12.90	7.97	15.17	0.85	129.13
25-11-2016	7:30	50.03	397	1.20	21.70	3.40	13.96	8.48	16.31	0.86	130.29
25-11-2016	7:35	50.05	395	1.20	28.40	3.00	17.01	9.45	19.47	0.87	131.71
25-11-2016	7:40	49.97	396	1.20	27.80	3.00	16.73	9.17	19.08	0.88	133.10
25-11-2016	7:45	50.01	394	1.20	23.80	3.00	14.60	7.18	16.28	0.90	134.32
25-11-2016	7:50	49.97	396	1.20	21.60	3.10	13.41	6.27	14.80	0.91	135.44
25-11-2016	7:55	49.97	396	1.10	21.70	3.00	13.56	6.22	14.91	0.91	136.57
25-11-2016	8:00	50.02	401	1.10	20.50	3.10	12.96	5.88	14.23	0.91	137.65
25-11-2016	8:05	50.04	402	1.20	14.30	3.30	9.29	3.65	9.98	0.93	138.42
25-11-2016	8:10	49.95	402	1.10	14.80	3.20	9.60	3.88	10.36	0.93	139.22
25-11-2016	8:15	49.91	401	1.09	14.80	3.20	9.56	3.85	10.31	0.93	140.02
25-11-2016	8:20	50.01	400	1.09	14.80	3.30	9.50	3.91	10.28	0.92	140.81
25-11-2016	8:25	50.01	400	1.10	14.40	3.40	9.26	3.80	10.01	0.93	141.58
25-11-2016	8:30	50.02	400	1.10	14.90	3.20	9.56	3.90	10.33	0.93	142.38
25-11-2016	8:35	49.96	398	1.09	14.60	3.30	9.42	3.71	10.12	0.93	143.16
25-11-2016	8:40	49.98	401	1.09	15.20	3.30	9.62	4.46	10.61	0.91	143.96
25-11-2016	8:45	49.93	401	1.09	15.00	3.20	9.63	4.04	10.44	0.92	144.77
25-11-2016	8:50	49.96	402	1.10	15.80	3.20	10.10	4.46	11.05	0.92	145.61
25-11-2016	8:55	50.00	400	1.20	16.10	3.30	10.29	4.34	11.17	0.92	146.47
25-11-2016	9:00	49.97	393	1.10	16.60	3.50	10.43	4.41	11.33	0.92	147.33
25-11-2016	9:05	49.94	393	1.10	17.20	3.50	10.57	5.02	11.71	0.90	148.21
25-11-2016	9:10	49.91	389	1.20	20.20	3.50	12.17	6.10	13.62	0.89	149.23
25-11-2016	9:15	49.89	385	1.10	24.30	3.30	14.79	6.68	16.23	0.91	150.46
25-11-2016	9:20	49.88	387	1.10	24.70	3.20	15.10	6.88	16.60	0.91	151.72
25-11-2016	9:25	49.93	387	1.09	25.20	3.10	15.39	7.01	16.91	0.91	153.00
25-11-2016	9:30	50.00	385	1.10	25.00	3.30	15.24	6.89	16.73	0.91	154.27
25-11-2016	9:35	50.10	385	1.10	23.90	3.50	14.67	6.29	15.96	0.92	155.49
25-11-2016	9:40	50.05	386	1.10	23.00	3.80	14.21	5.97	15.42	0.92	156.68
25-11-2016	9:45	50.00	390	1.10	22.50	3.80	14.04	5.87	15.22	0.92	157.85
25-11-2016	9:50	49.97	388	1.40	22.60	3.50	14.10	5.83	15.26	0.92	159.03
25-11-2016	9:55	49.96	387	1.50	23.00	4.10	14.26	5.99	15.47	0.92	160.21
25-11-2016	10:00	49.92	386	1.50	22.80	4.00	14.07	5.94	15.27	0.92	161.39
25-11-2016	10:05	50.05	387	1.50	22.90	4.10	14.18	5.97	15.39	0.92	162.57
25-11-2016	10:10	50.00	385	1.70	23.10	4.20	14.18	6.07	15.43	0.92	163.75
25-11-2016	10:15	49.92	383	1.60	23.70	4.10	14.44	6.32	15.76	0.92	164.95
25-11-2016	10:20	49.93	383	1.60	23.90	4.20	14.18	6.22	15.48	0.92	166.13
25-11-2016	10:25	49.95	382	1.60	23.30	4.20	14.17	6.13	15.44	0.92	167.31
25-11-2016	10:30	50.04	381	1.60	23.50	4.20	14.30	6.08	15.53	0.92	168.51
25-11-2016	10:35	49.98	382	1.80	23.30	4.40	14.15	6.22	15.45	0.92	169.68
25-11-2016	10:40	49.93	380	1.70	22.90	4.30	13.81	6.02	15.09	0.91	170.84
25-11-2016	10:45	49.94	380	1.70	22.60	4.30	13.80	5.73	14.95	0.92	171.99
25-11-2016	10:50	50.04	382	1.70	17.70	4.70	10.83	4.38	11.71	0.91	172.89
25-11-2016	10:55	49.99	380	1.80	21.60	4.80	13.17	5.50	14.28	0.92	173.99
Average/Total		50.01	404	1.48	11.83	3.85	7.36	3.20	8.93	0.94	#REF!
Maximum		50.00	379	1.48	21.50	3.80	18.77	1.63	20.66	0.91	

Performance analysis of AC Units

Particulars	Unit	HK block			Dalikin VRV-III	Library	VC hall
Design capacity, TR	TR	4	4	4	14 HP	3	11
Suction Filter area	m ²	0.19642	0.19642	0.19642	0.628605504	0.19642	0.39284
Average inlet velocity at filter	m/s	7	9.1	8.1	2.6	5.2	4.5
Inlet air flow	m ³ /s	1.37	1.79	1.59	1.37	1.02	1.77
	m ³ /h	4930	6435	5728	4948	3677	6364
	cfm	2911.6	3765.1	3369.2	2910.4	2162.9	3743.5
Inlet air conditions (Return)							
	dbt	27	27	27	27	27	27
	RH	65	65	65	65	65	63
Inlet air enthalpy	kJ/kg	68.7	69.7	68.7	68.7	68.7	67.4
Outlet air conditions (Supply)							
	dbt	33	38	36.5	37	38	36
	RH	34	22.5	25	22	23	26
Outlet air enthalpy	kJ/kg	62.4	64.3	63.99	61.2	65.47	63.8
Enthalpy difference	kJ/kg	6.3	4.4	4.71	7.5	3.23	3.6
Air density	kg/m ³	1.2	1.2	1.2	1.2	1.2	1.2
Air mass flow	kg/s	1.65	2.14	1.91	1.65	1.23	2.12
Cooling effect	kW	10.39	9.44	8.99	12.37	3.96	7.64
Tons of refrigeration	TR	3.0	2.7	2.6	3.5	1.1	2.2
Motor power	kW	4	4.3	4.2	3.8	3.2	3.8
Specific Energy Consumption	kW/TR						
		1.4	1.6	1.6	1.1	2.8	1.7

Particulars	Unit	HK block			Placement cell	Library	VC hall
Design capacity, TR	TR	4	4	4	14 HP	3	11
Inlet air flow	CFM	2912	3785	3369	2910	2163	3744
Inlet air conditions (Return) -	DBT, °C	27	27	27	27	27	27
Inlet air conditions (Return) -	RH, %	65	65	65	65	65	63
Outlet air conditions (Supply)	DBT, °C	33	38	36.5	37	38	36
Outlet air conditions (Supply)	RH, %	34	22.5	25	22	23	26
Tons of refrigeration	TR	3.0	2.7	2.6	3.5	1.1	2.2
Motor power	kW	4	4.3	4.2	3.8	3.2	3.8
Tons of refrigeration	TR	1.4	1.6	1.6	1.1	2.8	1.7

CONNECTED LIGHT LOAD DETAILS

Sl. No.	Section	NOI	FTL			CFL	LED	Fan	Computer	Total	Remarks
		400W	T12 (60W)	T8 (30W)	T5	11W	5W	70W	60W	KW	
1	SMV Block			109		491		93		12.923	
2	SBO Block			271		124		172		14.372	
3	SVN Block			93				109		7.004	
4	JNR Block			120		233		73		8.373	
5	RC Block			177				106		8.406	
6	CSE Dept.			146		67		123	203	7.746	
7	Library			181		24	30		87	9.102	
8	JK Block			116				144	90	5.668	
9	Placement Office					118		3		1.298	
10	REE Dept.		118			15	6	95	34	6.331	
11	MSCB		118			22		72	159	6.378	
12	ISE Dept.		168					140		9.776	
13	BSHE, CS, VP Dept		237		106			267	7	17.404	
14	Civil Engg. Dept.			150		12	6	90	32	7.362	
15	Hoarding Light	16								6.88	
Total		16	701	1483	186	1094	42	1526	612	125.8	
Total		5.93	36.452	71.164	3	12.958	0.31	104.75	36.72		
Total		5.3%	28.1%	54.8%	2.3%	9.3%	0.2%			100.4%	

LUX DETAILS (Day Time)

Sl. No	Location	Lux levels		Remarks
		Min Value	Max Value	
1	Electrical Room	80	545	
2	CS Block Entrance	200	300	
3	General Enquiry	209	400	T5
4	Reception	166	200	LED
5	Administration dept.	200	300	T5, LED
6	Help Desk	249	300	T5
7	Accounts & Finance	130	370	
8	Stair Case	65	300	
9	First Floor (Training & Placement cell)	123	190	LED, CFL
10	Class Room	115	130	
11	Second Floor Physics Lab	130	400	T12
12	Chemistry lab	142	200	T12
13	Third Floor, Lecture Halls	116	120	
14	Staff Room	217	400	
15	Library	96	300	T8
16	Adobe digital Lab	75	100	
17	Conference Hall	158	190	CFL, Halogen
18	Library basement	80	91	T8
19	Reading hall	80	95	T8
20	SMV Hostel Room:3	70	90	T8
21	SBS	200	499	CFL
22	Simulation lab	100	194	

Savings By Replacing T12/T8 Fluorescent Tube Lights by 18W LED Tube Light

Sl. No.	Location	Number of 40W fittings with inductive ballast	Number of T8 fittings with inductive ballast	Operating hour/day	Power savings Achieved		Cost savings achieved @ Rs. 7.56/kWh		Investment required	Simple payback period
					Daily kWh	Annual kWh	Daily Rs.	Annual Rs.		
a	Power consumption of 40 W fluorescent tube light with inductive ballast									52 W
b	Power consumption of 36 W fluorescent tube light with inductive ballast									48 W
c	Power consumption of 18 W LED tube light									18 W
d	Power savings by replacement of T12 with LED tube									33 W
e	Power savings by replacement of T8 tube with LED tube									28 W
f	Annual operating days									100 days
g	Cost of one LED tube light									900 Rs.
1	SMV Block		159	7	32.28	8455	250.92	51394.98	143100	2.8
2	SSIS Block		271	7	55.01	11003	437.90	87580.70	243900	2.8
3	SVN Block		163	7	33.09	8618	263.39	52877.89	148700	2.8
4	JGR Block		120	7	24.36	4872	193.91	38781.42	108000	2.8
5	RC Block		177	7	35.93	7186	286.01	57202.15	158300	2.8
6	CSE Dept.		146	6	25.40	5081	202.22	40443.17	131400	3.2
7	Library		181	16	83.08	16707	668.51	133702.83	162900	1.2
8	HK block		116	3	10.09	2018	80.33	16066.48	104400	6.5
10	EEE Dept.	118		3	11.68	2336	92.96	18587.74	106300	6.7
11	NSCB	118		3	11.68	2336	92.96	18587.74	106200	6.7
12	ISE Dept.	186		3	18.61	3722	148.15	29630.30	169200	5.7
13	SSHE, CS, VP Dept.	277		3	27.42	5485	218.29	43657.42	249200	5.7
14	Civil Engrg. Dept		150	3	13.06	2610	103.96	20775.60	135000	6.5
Total		701	1483		382.6	76520	3045	609098	1943600	3.2

T&E Report No. 2016/813

Diesel Generator

Measured power parameters of DG set

Measured power parameters of DG set																											
Date	Time	Hz	Voltage (V)			Vunb	Speed			Current (A)			Aunb			Sdnd			kW			kVA			PF	kWh	
			L1	L2	L3		%	L1	L2	L3	%	L1	L2	L3	%	L1	L2	L3	Sum	Sum	Sum	Sum	L1	L2			L3
23-11-2016	11:15	49.98	410	411	411	0.2	1.9	1.8	2.0	324	329	328	102.0	4.1	4.0	5.3	4.1	4.0	5.3	222	197	207	237	0.96	0.92	0.76	1.70
23-11-2016	11:16	49.98	410	411	410	0.2	1.9	1.8	2.0	329	329	329	102.8	4.0	4.1	6.5	4.0	4.1	6.5	225	358	421	238	0.96	0.92	0.54	7.46
23-11-2016	11:17	49.98	410	411	411	0.1	1.9	1.8	1.9	336	347	341	107.4	3.8	3.8	5.9	3.8	3.8	5.9	232	277	443	243	0.96	0.93	0.52	11.33
23-11-2016	11:18	49.98	410	411	410	0.1	2.0	1.9	2.0	334	344	339	107.2	4.1	4.0	12.0	4.0	12.0	219	227	277	243	0.96	0.92	0.69	14.87	
23-11-2016	11:19	49.98	410	411	410	0.1	2.1	2.0	2.1	331	348	339	113.4	4.2	4.0	7.2	4.2	7.2	221	238	246	238	0.96	0.95	0.57	18.88	
23-11-2016	11:20	49.98	411	411	410	0.1	2.1	2.0	2.2	321	351	336	102.8	4.7	3.9	5.0	4.7	3.9	5.0	231	238	311	238	0.96	0.92	0.74	22.51
23-11-2016	11:21	49.98	410	411	410	0.2	2.1	2.1	2.2	339	353	346	103.5	4.3	3.9	4.7	4.3	3.9	4.7	236	215	321	215	0.96	0.92	0.74	26.48
23-11-2016	11:22	49.98	410	411	410	0.1	2.2	2.1	2.2	332	344	338	114.7	4.0	3.7	6.1	4.0	3.7	6.1	229	214	319	214	0.96	0.92	0.73	30.33
23-11-2016	11:23	49.98	410	411	410	0.2	2.0	2.0	2.1	344	352	348	102.3	4.2	3.9	20.3	4.2	3.9	20.3	229	208	359	208	0.96	0.92	0.94	34.74
23-11-2016	11:24	49.98	409	411	410	0.2	2.1	2.0	2.1	346	349	348	102.3	4.2	3.9	17.3	4.2	3.9	17.3	233	218	508	218	0.96	0.95	0.92	41.83
23-11-2016	11:25	49.98	409	411	410	0.3	2.0	2.0	2.1	357	351	354	105.1	3.7	3.8	18.1	3.7	3.8	18.1	237	178	588	178	0.96	0.95	0.92	45.77
23-11-2016	11:26	49.98	409	411	410	0.2	1.9	1.8	2.0	353	362	358	112.0	3.4	3.3	5.1	3.4	3.3	5.1	237	178	585	178	0.96	0.95	0.92	49.77
23-11-2016	11:27	49.98	410	411	410	0.1	1.9	1.8	2.0	352	365	359	118.8	3.8	3.4	7.3	3.8	3.4	7.3	239	365	372	365	0.96	0.95	0.92	53.77
23-11-2016	11:28	49.98	410	411	410	0.2	2.2	2.0	2.2	378	378	378	111.9	3.7	3.4	6.1	3.7	3.4	6.1	247	124	277	124	0.96	0.92	0.99	57.71
23-11-2016	11:29	49.98	409	411	410	0.2	2.2	2.0	2.2	381	386	378	122.2	3.4	3.3	8.3	3.4	3.3	8.3	236	31	298	308	0.96	0.92	0.99	61.83
23-11-2016	11:30	49.98	409	411	410	0.2	2.1	2.0	2.1	389	376	373	120.4	3.7	3.5	10.3	3.7	3.5	10.3	252	61	267	265	0.96	0.92	0.98	65.70
23-11-2016	11:31	49.98	410	411	410	0.2	2.1	2.0	2.2	371	386	376	117.9	3.3	3.8	4.3	3.3	3.8	4.3	243	124	273	124	0.96	0.92	0.99	69.64
23-11-2016	11:32	49.98	410	411	410	0.3	2.2	2.0	2.2	357	353	355	113.8	3.5	3.8	4.0	3.5	3.8	4.0	250	113	273	113	0.96	0.92	0.91	73.52
23-11-2016	11:33	49.98	409	411	409	0.4	2.1	2.0	2.2	372	357	364	103.8	3.9	3.8	4.2	3.8	3.9	4.2	246	104	264	104	0.96	0.92	0.92	77.49
23-11-2016	11:34	49.98	408	411	409	0.3	2.2	2.1	2.3	363	353	358	103.8	4.0	3.9	4.2	4.0	3.9	4.2	249	105	270	105	0.96	0.92	0.92	81.37
23-11-2016	11:35	49.98	409	411	409	0.3	2.1	2.0	2.2	362	362	362	103.5	4.1	3.8	4.2	4.1	3.8	4.2	249	105	269	105	0.96	0.92	0.93	85.26
23-11-2016	11:36	49.98	409	411	409	0.3	2.1	2.0	2.2	363	370	366	8.8	4.0	3.3	4.1	3.3	4.1	251	98	269	269	0.96	0.92	0.93	89.20	
23-11-2016	11:37	49.98	409	411	410	0.2	2.1	2.0	2.2	363	370	366	7.3	4.2	3.8	4.8	4.2	3.8	4.8	242	95	261	261	0.96	0.93	0.93	93.10
23-11-2016	11:38	49.98	409	411	410	0.3	2.2	2.1	2.3	358	351	354	57.5	4.0	3.7	4.5	4.0	3.7	4.5	243	200	251	200	0.96	0.93	0.83	97.04
23-11-2016	11:39	49.98	409	411	410	0.2	2.0	2.0	2.2	355	353	354	48.5	3.8	3.8	4.8	3.8	3.8	4.8	247	180	305	180	0.96	0.93	0.77	100.94
23-11-2016	11:40	49.98	409	411	410	0.3	2.1	2.1	2.2	370	357	363	48.5	3.7	3.8	4.8	3.7	3.8	4.8	247	180	305	180	0.96	0.93	0.81	104.85
23-11-2016	11:41	49.98	409	411	410	0.3	2.4	2.3	2.5	390	363	372	8.2	3.8	3.9	4.5	3.8	3.9	4.5	251	100	270	100	0.96	0.92	0.83	108.78
23-11-2016	11:42	49.98	408	411	410	0.3	2.3	2.2	2.3	379	365	372	15.9	3.5	3.8	4.4	3.5	3.8	4.4	251	129	292	129	0.96	0.92	0.89	112.66
23-11-2016	11:43	49.98	409	411	410	0.3	2.3	2.2	2.3	379	365	372	24.1	3.5	3.8	4.8	3.5	3.8	4.8	242	141	280	141	0.96	0.92	0.90	116.58
23-11-2016	11:44	49.98	409	411	410	0.3	2.0	2.0	2.1	364	353	358	31.8	3.7	3.7	5.0	3.7	3.7	5.0	239	154	264	154	0.96	0.93	0.94	120.54
23-11-2016	11:45	49.98	409	411	410	0.3	2.0	2.0	2.1	358	346	352	31.8	3.7	3.7	5.0	3.7	3.7	5.0	239	154	254	154	0.95	0.92	0.94	124.84
Average Total	49.98	409	411	410	0.22	2.07	1.99	2.14	353	358	355	64.32	3.87	3.70	6.45	3.40	3.40	6.45	340	179	311	179	0.95	0.92	0.88	124.84	
Maximum	49.98	410	411	410	0.20	2.10	2.00	2.20	371	386	378	37.00	3.5	3.3	4.2	3.58	3.58	4.2	358	180	318	180	0.95	0.92	0.83	128.84	
Minimum	49.98	410	411	410	0.10	2.00	1.90	2.08	334	344	338	149.20	4.1	4.0	12.0	215	227	215	227	215	227	215	0.95	0.92	0.78	132.84	

TERI Report No. 2016/15

PERFORMANCE TEST OF THE 500kVA DG SET

Capacity of DG set	=	500 kVA
Test duration	=	31 Minutes
Units generated	=	123.84 kWh
Average load	=	239.69 kW
Diesel consumed	=	29.76 Litres
Average PF	=	0.89
Average operating load	=	269.31 kVA
% Loading	=	54%
Specific power generation	=	<u>4.16 kWh /Ltr.</u>

DG LOG SHEET

CUSTOMER NAME: ENGINE SR. NO:		MODEL:	ALTERNATOR MAKE:		ALTERNATOR FRAME:		VVA:	V/M:	ALTERNATOR Sr. No.:				
RT CLOCK	LUBE PRES. kg/cm ²	LUBE OIL TEMP.	WATER TEMP.	CURRENT (AMPS)			VOLTAGE (V)		POWER KW	POWER FACTOR (LEAD/LAG)	FREQ.	UNIT GENERATED KWH	HOUR METER READING
		Deg.C	Deg.C	R	Y	B	R-V	V-R	B-R		Hz		
Start Time													
12:00 AM													
1:00 AM													
2:00 AM													
3:00 AM													
4:00 AM													
5:00 AM													
6:00 AM													
7:00 AM													
8:00 AM													
9:00 AM													
10:00 AM													
11:00 AM													
12:00 PM													
1:00 PM													
2:00 PM													
3:00 PM													
4:00 PM													
5:00 PM													
6:00 PM													
7:00 PM													
8:00 PM													
9:00 PM													
10:00 PM													
11:00 PM													
ROOM TEMP. (DEG. C):													
Leakage's condition (If Not OK, Give details)													
<div> <div> Fuel system</div> <div> Cooling system</div> <div> Air system</div> </div> <div> Oil & Hoses</div> <div> Battery Charge / Al.</div> <div> Main Al / Panel</div>													

TEK Report No. 2020013



W O W

AN ITC INITIATIVE



ASSESSMENT REPORT FOR NEW HORIZON COLLEGE OF ENGINEERING

Contents

Waste Scenario in India	3
Who are we?	3
Purpose of the Assessment	4
Executive Summary	4
Rating Criteria.....	5
Rating.....	6
Waste Audit	7
Waste disposing Cycle.....	9
OBSERVATION	10
SWOT Analysis	10
Recommendations and Action items	12
Action Items.....	12
SNAPSHOT	16
Execution Timeline.....	23
Disclaimers	25

Waste Scenario in India

India faces major crisis associated with waste generation and improper waste disposal system. Current practices cannot bring a sustainable solution for reducing the dumping wastes in the country. Waste management system in the country has to be reviewed seriously and has to bring suitable changes to ensnare better collection system according to the waste generated. The challenges and barriers are significant, but so are the opportunities. A priority is to move from reliance on waste dumps that offer no environmental protection, to waste management systems that retain useful resources within the economy. Waste segregation at source and use of specialized waste processing facilities to separate recyclable materials has a key role. Disposal of residual waste after extraction of material resources needs engineered landfill sites and/or investment in waste-to-energy facilities. The potential for energy generation from landfill via methane extraction or thermal treatment is a major opportunity, but a key barrier is the shortage of qualified engineers and environmental professionals with the experience to deliver improved waste management systems in India.

Who are we?

ITC's Well-being Out of Waste (WOW) programme is a flagship initiative that seeks to address the crucial issue of waste management in line with the Government's 'Swachh Bharat' programme, ensuring the proper segregation and recycling of waste in a manner that protects and restores the environment, TC's WOW programme aims to create awareness among general public about the "Reduce-Reuse-Recycle" approach. The programme seeks to inculcate the habit of source segregation prior to collection of post-consumer waste.

Through WOW we support waste handlers who derive sustainable livelihood from this activity, recycling units who benefit from a steady source of identified and relevant waste, NGOs who train waste handlers and increase awareness about segregating waste among communities, and social entrepreneurs who avail of the opportunity to develop a sustainable business model out of waste collection. This programme is today being actively propagated and is receiving widespread support across 8 cities in South India, including Bangalore, Chennai and Coimbatore and 5 cities in Telengana with plans to extend it to other towns and cities as well. The WOW programme started with a collection of just 10 MT of recyclables in 2007 has now swelled to collections of over 20000 MT. Over 2100 waste handlers have gained sustainable livelihoods through this activity.

Purpose of the Assessment

The Purpose of the study is to understand and evaluate the waste disposal strategy adopted by different organizations. Analysis and observations will be purely based on the practices followed by organizations to reduce the risk of unsystematic waste disposal. Reports will be generated with appropriate suggestions to improve the Standards of waste management mechanism of within the organization. The process will help to access the organizational excellence in handling waste and further improve the quality of the process. The Reports with suggestions will be generated within 15 days of the process completion and the organization will be certified based on the Current practices adopted to manage the accumulated waste. The study will help Organizations to improve the standards of waste disposal in your organization.

Executive Summary




This waste assessment was conducted to determine the contents of the waste management strategy adopted by **New Horizon College of Engineering on the 22nd of November, 2018** in presenting a categorical analysis of this facility's waste, this report provides the necessary information to understand missed or underused recycling and waste management opportunities.

Areas of solid waste analysis provided in this waste assessment and recycling report include:

- *Availability of Bins as per SWM Rules*
- *Quality of Waste Disposal practised in the Organisation*
- *Practice and Quality of dry waste processing*
- *Practice and Quality of wet waste processing*
- *Waste monitoring*
- *Innovation*
- *Usage of safety equipment by people Handling*
- *IEC Programmes*

Rating Criteria

(Table. 0.1)

Marks Obtained	Stars	Grade
161-200		A
121-160		B
81-120		C
41-80		D
0-40		E

Rating




(Table. 0.2)

Total Marks Obtained: 56

Belt: BROWN


Streams	Grades
<i>Availability of Bins as per SWM Rules</i>	B
<i>Quality of Waste Disposal practised in the Organisation</i>	C
<i>Practice and Quality of dry waste processing</i>	D
<i>Practice and Quality of wet waste processing</i>	B
<i>Practice and Quality of other category of wastes processing</i>	C
<i>Waste monitoring</i>	C
Innovation	C
<i>Use of safety equipment by people Handling</i>	C
<i>IEC Initiatives and Capacity building for waste handlers</i>	D

Waste Audit



Waste Generation Pattern (Figure. 0.1)



Out of the total waste generated from the organization, the highest amount of waste generated is the Wet waste comprising 42% of the total waste generated at the organization, followed by dry waste generation comprising 33% of the total waste generated in the organization. Sanitary waste comprises just about 10% of the total waste generated by the organization followed by E- waste comprising 10% and other waste occupies 5% of the total waste generated at the organization.



Sources of waste segregation (Figure. 0.3)

Out of the total waste generated from around the campus, the highest source of waste is generated from the cafeteria and the kitchen, comprising 25% each of the total waste generated around the campus, followed by the waste generated from the cubicles/office and the printing areas comprising 13% each of the total waste generated followed by the waste generated from the cubicles, the corridors and the classrooms generate relatively lesser waste comprising 9% and 8% respectively followed by the waste generated from the visitors room and the auditorium comprising 4% of the total waste generated in the organization. The least amount of waste is generated from the bathroom comprising just 3% of the total waste generated in the organization.

Waste disposing Cycle



OBSERVATIONS

- The availability of composting machine is seen as a good practice when it comes to handling the wet waste. The garden within the campus is provided with their share of manure from the wet waste converted into manure but only if 100% segregation is reached can the gardens get more manure.
- The availability of separate places allocated for the segregation before the collection is very helpful in many ways but again, segregation at source would make the process even smoother.
- Hence, proper monitoring and evaluation at the collection point of waste at the organization is needed for smoother functioning.
- The total area of the campus has been maintained very well when it comes to the cleanliness.
- The usage of the steel plates and spoons and forks in the cafeterias is a good practice as it contributes to the reduction of the waste generation in the organization to a certain degree. This brings about the reduction in the usage of plastic.
- The idea of segregation of waste at source has been implemented as there are separate bins such as: red for hazardous waste, blue for dry and green for wet waste, though it is yet to be implemented in the rest of the premises.
- The allocation of separate bin for the disposal of hazardous and E-Waste is also seen as a good practice ensuring safe disposal of the same.
- The organization should ensure that the cafeteria also implements the concept of waste segregation. The cafeteria has many dust bins but all contains mixed waste.
- The organization should ensure that separate bins with color codes needs to be allocated in and around the campus.
- It has been observed and learnt that there is a lack of written policies with respect to the waste management in the organization. There are rules regarding littering with penalties (the lawn in the campus and it has been well implemented), though the rules aren't specifically directed to waste segregation.
- Housekeeping staff have been rightly allocated the work and they are lifting the waste from various points. The staff has been provided with the various safety equipments such as safety gloves, uniforms and shoes.
- The organization has just one dust bin in the ladies washroom. Allocation of dustbins in every cube would be better for the Ladies.
- Housekeeping staffs requires trainings on waste management practices.

- There is a need for placing sign boards directing to the bins and CCTVs around the areas of the dust bins can have an effective implementation.

SWOT Analysis



Strength

- Openness to review the waste management system in the organization.
- Availability of infrastructure and resources to manage their waste in a more efficient manner.
- Usage of steel plates in the cafeteria thus reducing the waste.
- The organization has ensured proper safety measures for the housekeeping staff.



Weakness

- Not streamlined the processing of dry, wet and sanitary wastes in all the areas.
- Lack of awareness among the staff and students about the concept of waste segregation.



Opportunity

- 100% of the wet waste generated at the organization can be composted as there is a composting machine that is available at the organization.
- Interest in conserving the environment as the campus also follows certain eco friendly measures such as the usage of steel plates.
- 100% segregation of waste can help generate more resources.



Threat

- Mixed waste present in the various areas around the campus. (Lack of segregation at source).
- Lack of written policies with respect to waste management.

Recommendations and Action items

Streams	Action Items
<i>Availability of Bins as per SWM Rules</i>	<ul style="list-style-type: none"> • Recommend to maintain a database records/ Maps of places where bins are located and list of people attending each waste disposal points. • Need to Place and monitor the image of bins and signage in all the premises of the organization ensuring proper segregation of waste at source. • Need to have separate bins that clearly indicate the type of waste by following the colour codes. • It is highly recommended for the organization to have closed bins for Wet Waste Bins available in the organization. • There should be proper monitoring when it comes to the bins in the cafeteria as the buckets allocated for the purpose of putting the plates have been used for discarding the general waste as well. Hence, the allocation of separate containers for the plates and separate ones for the disposal of food waste is highly suggested.
<i>Quality of Waste Disposal practised in the Organisation</i>	<ul style="list-style-type: none"> • The organization should definitely take strict actions when it comes segregation at source. • The organization should ensure proper segregation and monitoring in the

	<p>storage facility allocated for every category of waste.</p> <ul style="list-style-type: none"> • A team can be formed from the employees to uphold this task.
<i>Practice and Quality of dry waste processing</i>	<ul style="list-style-type: none"> • Dry waste should be given to registered recyclers or recycling associates to ensure that the dry waste is not going to the landfill. • Confidential papers should be shredded. • The stakeholders should provide certificate of disposal along with the end-to-end data of the total waste collected and processed from their organization be it Dry, Wet and Sanitary, e-waste and hazardous waste.
<i>Practice and Quality of wet waste processing</i>	<ul style="list-style-type: none"> • The organization should ensure that 100% of the wet waste should be composted since there is a composting machine available at the organization. This makes it possible for the organization to minimize their waste handling cost and the impact on the environment. • Organisation should avoid the usage of liners. If at all there is a need for the use of liners, it should be of either paper or biodegradable plastics. • The biodegradable waste should be responsibly treated by the organization through approved methods such as composting by using authorized OWC machines, in-house composting, or

	<p>convert the biodegradable waste into gas through the process of bio-methanation., etc</p>
<i>Practice and Quality of other category of wastes processing</i>	<ul style="list-style-type: none"> • Source segregation is highly recommended. • A drive for the collection of E-Waste can be conducted to ensure that the e-waste has been collected. • The E-waste can further be treated scientifically. Hence being associated with approved vendors for the treatment of e-waste is highly recommended. • Sanitary waste needs to be scientifically disposed. Installment of sanitary napkins incinerators in the Ladies washroom is highly recommended so that sanitary waste can be disposed off at source, saving time and energy in the process. This would make the users/generators conscious about their own responsibilities.
<i>Waste monitoring</i>	<ul style="list-style-type: none"> • Develop a systematic waste management policy and execution plan in the organization. • Organisation should try to review the waste management strategy at least once in six months. • Availability of CCTVs at the collection points and other relevant areas.

Innovation	<ul style="list-style-type: none"> • Conduct a hack sessions, essay competition, art sessions, etc., among students and faculty members in alignment with the thought green initiatives. • The organization is recommended to develop replicable models and strategies in terms of waste management.
<i>Use of safety equipment by people Handling</i>	<ul style="list-style-type: none"> • Proper monitoring should be carried out to ensure that the housekeeping staff should follow all the measures of their safety and that it is taken seriously. • The organization should ensure that the employees working in handling the waste needs to be briefed about the importance of their own personal health and hygiene through training sessions etc.
<i>IEC Initiatives and Capacity building for waste handlers</i>	<ul style="list-style-type: none"> • Organisation should conduct training programmes for the house keeping staffs, and employees on source segregation, health and hygiene, environmental consciousness etc., on a regular basis. • Promote and implement the concept of Reduce, Reuse and Recycle ensuring circular economy within the organization in the process through the circulation of mailers among the students and employees.

	<ul style="list-style-type: none">• Occasions such as World Clean Up Day, World Environment Day, World Recycling Day can be celebrated in ways that can bring about awareness and consciousness among the entire members in the organizations.• Clubs and groups and teams can be formed within the university and certify the students for their participation and contribution.• Regular trainings regarding the strictness among the housekeeping staff should be conducted for the smooth implementation of the waste segregation.
--	--


SNAPSHOTS



Segregated bins in the classroom and the corridors inside the buildings.



Snapshots of waste bins from around the campus.



The scenario at the cafeteria and the eating places in the campus



The dumping point of the organization



The Availability of the OWC Machine in the dumping point for wet waste.





The housekeeping staff with their protective gears

Execution Timeline

Day 1- 30 (PHASE ONE)

- Training the housekeeping staff and the employees in the organization
- Team formation for monitoring the waste management system in the organization
- Preparing a plan for addressing the issues mentioned in the waste assessment report.
- Purchasing the necessary materials required for the same.
- Ensuring availability of dust bins in required spaces.
- Ensuring the maintenance of the color code of the dust bins.

Day 31 – 60 (PHASE TWO)

- Reviewing the dry and wet waste disposal system in the organization
- Reviewing the vendors dealing with the dry and wet waste.
- Coming up with a strategy to dispose dry wet and sanitary waste in a proper way.
- Sending mailers and putting posters around the campus ensuring awareness among the employees in the organization in terms of waste segregation

Day 60 – 90 (PHASE THREE)

- Periodic review of the Existing waste management system
- Constructing effort to reduce the plastic usage in the campus
- Implementing in house composting plan.
- Organizing training and awareness campaigns amongst the employees on waste segregation (refresher)
- Ensure the vendors are collecting dry waste at the right time and appropriate certificates have been provided.

Day 91 – 120 (PHASE FOUR)

- Reviewing the waste management mechanism in the organization
- Team allotment for addressing the waste management issue. Team should come up with the challenges and other issues that need to be addressed
- Ensure whether the issues related to dry waste and sanitary waste is managed properly.

- Ensure that the housekeeping staff is following proper safety measures by using proper safety equipments.

Day 121 – 180 (PHASE FIVE)

- Regular monitoring
- Ensuring the regularity in terms of collection of dry waste and composting of wet waste.
- Ensuring that the confidential papers are being shredded
- Planning for some innovative designs that can be improvised or used in the organization to ensure efficacy in their waste management system.

Disclaimers

- Analysis and observations will be purely based on the practices followed by organization with regard to waste management.
- The Report will be provided within 15 days after conducting the assessment
- The trainings for the house keeping staffs as well as for the employees will be scheduled according to the organizations preferences and availability of participants
- Re assessment will be done 6 months after the initial assessment and the organization will be certified as per the results of the second assessment
- The assessment report will be kept confidential and will not be shared with anyone
- Please discuss with the Assessment team in case of any dispute in terms of report generated.
- Please coordinate with the Assessment team for any support required in the area of waste Management